



LAKE COUNTRY

Life. The Okanagan Way.



Water Operations 2016 Annual Report

10150 Bottom Wood Lake Road
Lake Country, British Columbia V4V 2M1
Ph: 250-766-6677 Fax: 250-766-0200
lakecountry.bc.ca

LAKE COUNTRY

DISTRICT OF LAKE COUNTRY

Water Operations Annual Report - 2016

Prepared For:
INTERIOR HEALTH AUTHORITY
1440 – 14th Avenue
Vernon, BC V1B 2T1

Prepared By:



Patti Meger, Water Quality Technician




Brent Lashuk, Water Quality Assistant, term Co-op

Reviewed By:



Kiel Wilkie, Engineering Tech. I



Mike Mitchell, Utility Superintendent



LAKE COUNTRY

Life. The Okanagan Way.

Table of Contents

1. 2016 OVERVIEW	- 5 -
1.1 <i>System Description and Classification</i>	- 5 -
1.2 <i>Water Demands</i>	- 5 -
1.3 <i>Water Sources</i>	- 7 -
1.4 <i>Cross Connection Control Program</i>	- 8 -
1.5 <i>Annual Operation Summary</i>	- 9 -
1.5.1 <i>2016 Operations Project Highlights</i>	- 9 -
1.6 Capital Works Improvements	-10-
1.7. Emergency Response Plan	-11-
2. DISTRIBUTION WATER QUALITY SUMMARY	- 11 -
2.1 <i>Water Chemistry Background</i>	- 11 -
2.2 <i>Bacteriological Background</i>	- 13 -
2.3 <i>Beaver Lake Source</i>	- 15 -
2.4 <i>Okanagan Lake Source</i>	- 16 -
2.5 <i>Oyama Lake Source</i>	- 17 -
2.6 <i>Kalamalka Lake Source</i>	- 17 -
2.7 <i>Coral Beach Water System</i>	- 18 -
2.8 <i>Lake Pine Water System</i>	- 18 -
2.9 <i>Water Quality Advisory and Boil Water Notice</i>	-19-
2.10 <i>Service Disruptions</i>	- 19-
2.11 <i>Trihalomethanes (THM's)</i>	- 20 -
3. INSTRUMENT CALIBRATION AND QUALITY CONTROL	- 24 -
4. GIARDIA PERFORMANCE MONITORING	- 24 -
5. SOURCE SAMPLING (RAW WATER)	- 25 -
5.1 <i>Raw Water Reservoirs/Intakes</i>	- 30-



6. WATERSHED MANAGEMENT - 32 -

 6.1 Range Management - 34 -

 6.2 Forestry - 36 -

APPENDIX A – SUMMARY OF POSITIVE BACTERIOLOGICAL RESULTS IN DISTRIBUTION - 37 -

APPENDIX B – DISTRICT OF LAKE COUNTRY SAMPLING SITES - 38 -

APPENDIX C – 2016 GIARDIA PERFORMANCE MONITORING - 41 -

APPENDIX D – COMPREHENSIVE TEST RESULTS - 44 -

APPENDIX E – NUTRIENT SAMPLING DRINKING WATER RESERVOIRS BEAVER LAKE OYAMA LAKE - 46 -

APPENDIX F – 2016 BEAVER & OYAMA LAKE LEVELS AND DISCHARGE BEAVER LAKE OYAMA LAKE - 48 -

APPENDIX G – DROUGHT FORECAST FOR BEAVER AND OYAMA LAKES - 50 -

APPENDIX H – Water Source Area Map - 52 -

APPENDIX I – Kalamalka UV Station Log Sheets - 53 -

APPENDIX J – Operators Current ECP Information - 65 -

1. 2016 Overview

The following is intended to inform and summarize 2016 data collections, observations, and work completed by District of Lake Country staff with regards to water operations and water quality.

Water operations highlights include the continuation of the Universal Water Metering project, cleaning and inspections of the Oyama Creek intake and Vernon Creek intake, and the installation of agriculture water meters on Vernon Creek source.

1.1 Systems Descriptions and Classification

The District of Lake Country is a growing municipality with an approximate population of 14,000 people. Not all of these 14,000 residents are connected to the District's regulated water systems. The primary upland sources regulated by the District include the reservoirs at Beaver Lake, Crooked Lake, Oyama Lake, and Damer Lake. The lower elevation reservoirs are Okanagan Lake (3 separate intakes) and Kalamalka Lake.

Infrastructure within the District owned water systems includes 6 storage dams, 9 reservoirs, 6 chlorine injection systems, 8 pump houses, 3 pressure boosting stations, 35 pressure reducing stations, 77 pressure reducing valves, more than 400 hydrants and approximately 200 km of water distribution mains.

1.2 Water Demands

Each water source or water system within the District has varying levels of consumption demand. The primary factors that affect demand are the total number of connections to the water system and the type of water connection. Residential, commercial, industrial, institutional, seasonal irrigation and agricultural connections are all different types of customers connected to the different water systems. Total water use among the different sources and water systems in 2016 was 8,620,392 cubic meters (see Figure 1 for water consumption by source).




Figure 1. Graph of 2016 water demands with all sources.

Figure 1 Analysis:


- 2016 was an average water consumption year with an average year’s consumption being 8.6 million cubic meters.
- Zero consumption on Oyama Creek source occurred during low consumption months. This is because during low consumption months, traditional Oyama Lake customers are supplied with Kalamalka Lake water.
- Large increases on the Okanagan Lake supply and Kalamalka Lake supply in spring.
 - o During the spring freshet the water flowing from the upland waters tends to have increased particulate in the water due to snow melt. This contributes to a period of increased turbidity and color on these water sources. Therefore the District supplies Kalamalka Lake water to the typical Oyama Creek customers and Okanagan Lake water to the typical Beaver Lake customers during spring freshet. The Okanagan Lake and Kalamalka Lake source typically exhibits higher drinking water quality characteristics than the Oyama and Beaver Lake sources.
- With unseasonably warm temperatures beginning in early April, water consumption was set to be record high but heavy rainfall from May through July slowed usage drastically. Typical summer temperatures returned in July and August which correlates to the usage peak seen in Figure 1.

1.3 Water Sources

The District uses and monitors four separate water sources:

1. Beaver Lake (Crooked Lake chain flows into Beaver Lake)
2. Oyama Lake (Damer Lake flows into Oyama Creek)
3. Okanagan Lake
4. Kalamalka Lake

See appendix H for source area map.




Crooked Lake dam spillway (left) and Oyama Lake dam spillway (right).

The Oyama Lake snow pack for 2016 was very high. February through to the beginning of April showed the largest volumes of snow recorded in the last 5 years. The water equivalence was nearly double that of 2015 at the end of February with volumes of 95 mm and 174 mm for 2015 and 2016, respectively. To see the historical snow survey data for Oyama Lake please visit the [BC River Forecast Centers website](#), under manual snow survey data, number 2F19.

See Appendix F for 2016 Oyama and Beaver Lake level and Discharge.

During spring freshet and heavy rain events, large quantities of water flow through both Beaver Lake and Oyama Lake sources, commonly causing large spikes in turbidity and colour. When water quality becomes compromised due to rapid increased flows, the District switches upland source customers (Beaver and Oyama Lake) to lower elevation sources (Okanagan and Kalamalka Lake).



Eldorado drinking water reservoir (left) fed by Vernon Creek Intake (right).

1.4 Cross Connection Control Program (CCCP)

The Universal Metering program along with the installation of testable backflow prevention devices on seasonal irrigation connections reached 98% completion in 2016. The majority of seasonal irrigation connections, primarily for agricultural use in the District, were inspected and fitted with the appropriate cross connection control device, with the remainder to be completed in 2017. Risks encountered with domestic services were also addressed at this time.

Dependent on the business type, any new business license issued by the District will be subject to an inquiry as to the use of water for that business. If warranted, a cross connection inspection will be completed.

Table 1. *Status of cross connection control program noting the severity of hazards and the number of those that were surveyed as being compliant.*

Hazards	Quantity	Not Surveyed	Surveyed	Vacant	Compliant
High	40	3	37	0	33
Medium	88	12	76	0	62
Low	90	14	76	0	64
Totals	218	29	189	0	159

1.5 Annual Operations Summary

Annual operational duties that are completed by District staff:

- Service installation and repairs
- Collection and analysis of water sampling
- Upland dam inspections
- Maintain and clean all reservoir, chlorination, and pumping facilities
- Water main flushing
- Air valve maintenance
- Pressure reducing valve maintenance
- Hydrant maintenance
- Line valve maintenance
- Main line leak repairs
- Seasonal irrigation turn on & off
- Respond to customer complaints and inquiries

1.5.1 2016 Operations Project Highlights:


Universal Metering Program

The installation phase on the Universal Metering project continued from 2014 and reached 98% completion by the end of 2016. This project accounts for 2000 residential installations and upgrades to over 800 existing metered accounts so they are compatible with the new system. It also encompasses the installation of agricultural meters which neared completion in Winfield, Okanagan Centre, and Carr's Landing areas in 2016. The remaining domestic and agricultural installations will be completed in early 2017.

The District's Water plan remained the same in 2016, with a water **SAFE** vision of providing water that is **Sustainable and Affordable For** community and **Environment**. The project's primary objective is to have water consumption meters installed on all domestic, agricultural and industrial, commercial and institutional (ICI) service connections that are connected to a District water source. Metering will help to ensure water supplies are safe and sustainable as a whole.



Neptune Meter and Apollo Backflow installed (left) and District installing a Meter and Backflow unit (right)



Neptune Meter contractor installing residential indoor meter (2015)

Dam and Reservoir Inspections

Weekly and daily inspections of Upland Dams (Beaver, Crooked, Oyama, and Damer) were completed by the District. All inspection reports outlined the conditions of the dams and reservoirs as well as any maintenance recommendations.

The provincial inspector, Mike Norsworthy, completed a dam audit on Damer/Oyama Lake.

2016 also included the cleaning and inspection of the Coral Beach reservoir. There were no issues with any of the hardware or infrastructure.

1.6 Capital Works Improvements

The District of Lake Country continues to progress towards the goal of sustainable and affordable water following projects outlined in the [Water Master Plan](#). Project 2 (Universal Metering) reached 98% completion in 2016 and will be completed in early 2017. Project 3, regarding Lower Lakes Water Quality Improvements, was next to be completed but was delayed and replaced by Project 4, Eldorado Treated Water Reservoir. The engineering and design phase of the Eldorado treated Water Reservoir began in 2016 with an anticipated start date of June 1, 2017 and is set to be completed March 31, 2018.

Due to the primary objective of supplying high quality water to domestic customers, the Eldorado Improvements took precedence over the Lower Lakes Improvements. The Eldorado reservoir is supplied with Vernon Creek water from the Beaver Lake source. This water source is susceptible to elevated turbidity and microbiological contamination, especially during freshet. The design of the Eldorado Treated Water Reservoir will increase treated water storage volumes and provide greater chlorine contact time for better disinfection.

Three key structures are involved with the completion of the Eldorado Improvements project. The Eldorado Treated Water Reservoir, Eldorado Low Lift Booster Station, and Glenmore Road Booster Station.

The Eldorado Treated Water Reservoir is a 6,000 m³ storage reservoir. It will be located next to the existing Eldorado Raw Water Reservoir. The Eldorado Low Lift Booster Station is required to pump water from the current raw water reservoir up to the new treated reservoir.

The Glenmore Road Booster Station facilitates staffs ability to pump Okanagan Lake water into the Beaver Lake Water System. This is important during spring freshet when increased turbidity in Vernon Creek causes that source to become compromised. This new booster station replaces an existing booster station. The new booster station will have greater pumping capacity and greater operation redundancy.

1.7 Emergency Response Plan

The DLC has developed an Emergency Response Plan (ERP) that is updated annually (or more often as required). This report is separate from the Annual Water Operations Report. Both the ERP and Annual Water Operations Report are provided to IHA annually in June.

2. DISTRIBUTION WATER QUALITY SUMMARY

2.1 Water Chemistry background

This section provides a review of the water quality testing performed in 2016 for the District of Lake Country's (DLC) water sources. Overall bacteriological and water chemistry results show that the District's drinking water is safe to drink. However, some parameters exceeded the maximum acceptable concentrations under the [Guidelines for Canadian Drinking Water Quality \(GCDWQ\)](#). The District's two main upland drinking water reservoirs (Beaver and Oyama Lakes and their creek sources where our intakes are located (Vernon and Oyama Creeks) exceeded the [GCDWQ](#) for colour and turbidity. Both Beaver and Oyama sources exceeded the THM guidelines. Such results are common throughout the Okanagan wherever water is sourced from highland watersheds.

Source water from these watersheds is high in organic matter which causes colour issues and elevated disinfectant by-products. Turbidity is naturally occurring in some areas and can be compounded by human activities that occur above our intakes, such as recreation, cattle ranching and logging. The DLC is working towards treatment (as outlined in our [Water Master Plan](#)) and at present our primary form of disinfection is chlorination.



Vernon Creek covered in snow (above).

Water purveyors are responsible for providing potable water to their users under the [BC's Drinking Water Protection Act](#). In November 2012 the Province released version 1.1. for Drinking Water Treatment Objective (microbiological) for surface water supplies in British Columbia ([BC Drinking water objectives](#)). The [BC Drinking water objectives](#) provide an overview of the *framework towards achieving goals for drinking water treatment of pathogens in surface water supply systems in BC and for a general reference for assessing progress towards updating or improving existing water supply systems*. This general overview was developed using the [BC's Drinking Water Protection Act](#), the [Drinking Water Protection Regulation](#), and objectives in the [GCDWQ](#). It will be used as a general reference for assessing progress towards updating or improving existing water supply systems. The treatment objectives ensure the provision of

microbiologically-safe drinking water. It provides minimum performance target for water suppliers to treat water to produce microbiologically-safe drinking water addressing enteric viruses, pathogenic bacteria, Giardia cysts and Cryptosporidium oocysts. This continues to follow the 4-3-2-1-0 treatment objectives:

- 4-log (99.99 percent) inactivation and/or removal of viruses,
- 3-log (99.9 percent) inactivation and/or removal of Giardia and *Cryptosporidia*,
- Two treatment processes for surface water
- Less than or equal to one nephelometric turbidity unit (NTU) of turbidity
- No detectable E.coli, fecal coliform and total coliforms

COST
The total cost of the Water Master Plan is estimated at \$79 million over 20 years funded through developer contributions, grants and user rates.

USER RATES
Will be finalized by Council during the Budget Process & Water Rates Bylaws review in Spring 2012. Proposed residential user rates increase to \$600/year in 2012 and \$700/year in 2013. Agricultural rates were \$77 per acre in 2011 and proposed to increase \$4 per acre per year for 10 years.

RESPONSIBILITY
The replacement cost for District-owned water utility assets is estimated at one hundred million dollars. We all have an ownership stake in District-owned assets.

BOIL WATER NOTICES
New water treatment facilities using a combination of ultra-violet and filtration technologies provide enhanced treatment and eliminate the need for water quality advisories and boil water notices.

AGING INFRASTRUCTURE
The plan will rehabilitate aging infrastructure that is old and failing. What happens if the infrastructure fails?

MORE CAPACITY
Increased reservoir capacity will provide required peaking, fire and emergency storage.

WATER CONSERVATION
Universal metering fosters conservation and enables equitable billing (you pay for what you use).

WATER USE
The average Okanagan resident uses 675 litres of water each day, twice as much as the average Canadian - 329 litres per day.

AFFORDABLE
\$1.33/day will buy \$79 million in projects over the next 20 years. Only a few municipalities in BC have accomplished as much.

NEXT STEPS
The completed Water Master Plan document will be presented to Council for endorsement in the Fall of 2011 & for final budget approval in Spring 2012.

“Water is an important issue for Lake Country residents. Council wants to make sure it is as safe and clean as possible, while still being affordable,” says Mayor James Baker. “Our new Master Plan will save us money in the long run, but only if we start to invest in our water system now.”

“Municipalities need to be proactive in funding infrastructure and levels of services for the future. We can either let infrastructure gradually degrade and adapt or set aside sufficient funds to be prepared.”
Alberto De Leo, Chief Administrative Officer

LAKE COUNTRY
Life. The Okanagan Way.

Water Master Plan

To achieve the vision for future water system investments, the District of Lake Country recently completed a Water Master Plan. This Plan provides a broad assessment of the District's future water source, treatment, and distribution needs, and it proposes a number of infrastructure improvements that will help the District to fulfill legislative requirements and recent directives from the Interior Health Authority.

Since November 2010 the District engaged in developing the Water Master Plan and presenting information to the community, following a public consultation process of displays, presentations, surveys and an Open House. Council endorsed the Water Master Plan in principle on July 19, 2011. The majority of the feedback received from the community indicated that while they were not delighted with the increase in user rates, the necessity of improving and protecting Lake Country's water was recognized.

Sustainable

Affordable

For our community, and

Environment

Tell us What You Think

Mail ~ 10150 Bottom Wood Lake Road, Lake Country, V4V 2M1
Phone ~ Greg Buchholz, Operations Manager 250.766.6677
Email ~ engineering@lakecountry.bc.ca
Online Survey ~ www.surveymonkey.com/s/RK6DHDP

Water Master Plan concept promotional marketing (above).

The District has addressed these concerns in our [Water Master Plan](#) and we remain in discussions with IHA regarding the implementation and challenges of meeting these requirements

The DLC's distribution sites are monitored throughout the year for water chemistry, (free and total chlorine, turbidity, temperature, pH and conductivity) and for the presence of bacteria (total coliforms and E.coli).

Chlorine is the disinfectant used for all of the District sources. Free and total chlorine are measured to ensure a residual is maintained throughout the distribution systems. The Kalamalka Lake source also utilizes ultraviolet water treatment radiation as a secondary form of disinfection. Ultraviolet operations log sheets are contained in Appendix I.

Turbidity (a measure of the amount of particulate matter suspended in water) can harbour microorganisms protecting them from disinfection, therefore increasing the chlorine demand. In the Canadian Drinking Water Guideline ([GCDWQ](#)) the maximum allowable concentration for turbidity in water distribution systems has been set at 1 NTU.

Temperature and pH affect the strength of the disinfectant. The potable water temperature should be less than 15 °C for palatability and to inhibit growth of nuisance organisms. [GCDWQ](#) for pH ranges between 6.5 and 8.5.

Conductivity (the ability of an aqueous solution to carry an electrical current) is used as a quick indicator of changes occurring in the natural waters.

Colour creates high disinfectant demands and is an indicator of potential increased dissolved organic matter which, when combined with chlorine, forms disinfectant by-products. There is no GCDWQ for apparent colour however the aesthetic objective in the GCDWQ for true colour is <15 TCU.

2.2 Bacteriological Background

The District of Lake Country (DLC) in cooperation with the Interior Health Authority, Okanagan Service Area (IHA) has developed a Water Quality Monitoring and Reporting Plan. It includes the criteria set by the Province to ensure standards for the monitoring the delivery of safe drinking water are being met. The bacteriological water quality monitoring requirements that DLC follows measure against the Guidelines for Canadian Drinking Water Quality ([GCDWQ](#)) and the [Drinking Water Protection Act \(DWPA\) and Regulations \(DWPR\)](#). Drinking Water Samples are collected on a weekly basis within each DLC Water System. Each water source is monitored for physical, chemical, and biological parameters. All membrane filtration microbiological samples are sent to an accredited and licensed laboratory for analysis. Additionally, samples are analyzed 'in-house' with presence absence tests (P/A) for further measurement against the [GCDWQ](#) and for use in assessing trends, standards and emerging issues. The required numbers of monthly samples are detailed in the [DWPR](#) Schedule B (Table 1) and the District of Lake Country Water Quality and Monitoring Plan; Frequency of Monthly bacteriological tests (Table 2). All weekly Total coliform and E.coli results from raw water sources and throughout the distribution system (this includes both membrane filtration and Presence-Absence) are compiled and submitted to the Drinking Water Officer assigned to DLC, Coral Beach and Lake Pine water systems. Results that do not meet the water quality standards in The [DWPR](#), [Schedule A \(Table 3\)](#) are immediately reported to the Drinking Water Officer.

Table 1: Schedule B – Frequency of Monitoring Samples for Prescribed Water Supply Systems (section 8).

Population Served by the Prescribed Water Supply System:	# Samples per month:
less than 5,000	4
5,000 to 90,000	1 per 1,000 of population
more than 90,000	90 plus 1 per 10,000 of population in excess of 90,000

Table 2: Frequency of Monthly bacteriological tests: Membrane Filtration (MF) and Presence-Absence (P/A)

System/Source	MF Distribution # samples required per mo.	MF Raw Water # samples recommended per mo.	P/A	Total MF Distribution and Raw	Distribution Bacteriological/ Chlorine test sites:
DLC Water System: Beaver Lake source : Est. Population 4,000	4	4	2	8	15*
DLC Water System: Okanagan Lake source : Est. Population: 4,000	4	4	2	8	11**
DLC Water System: Oyama Lake source: Est. Population 636	4	4	2	8	6
DLC Water System: Kalamalka Lake source: Est Population 614	4	4	2	8	5
Coral Beach Water System: Okanagan Lake source Est Population 124	4	4	2	8	2
Lake Pine Water System: Okanagan Lake source Est Population 173	4	4	2	8	4**
*includes Camp Rd. Reservoir (offline until required)					
**includes at least 2 reservoirs					

Table 3: Schedule A - Water Quality Standards for Potable Water (sections 2 and 9) DWPR

Parameter:	Standard:
Escherichia coli (<i>E.coli</i>)	No detectable Escherichia coli (<i>E.coli</i>) per 100 ml
Total coliform bacteria:	
(a) 1 sample in a 30 day period	No detectable total coliform bacteria per 100 ml
(b) more than 1 sample in a 30 day period	At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml

Coliform bacteria are naturally occurring in the environment and generally are not harmful. However, their presence is an indicator for the presence of other types of disease-causing organisms. The presence of these bacteria is a sign that there may be problems with the water treatment, or the water distribution system.

Escherichia coli, (*E.coli*) is a bacterium that is always present in the intestines of humans and other animals and whose presence in drinking water would indicate fecal contamination of the water. Most strains of *E.coli* do not cause illness in healthy humans, although some strains do cause cramps and diarrhea. One particular strain named O157:H7 produces a powerful toxin that can cause severe illness. The maximum acceptable concentration (MAC) of *E.coli* in public, semi-public, and private drinking water systems is zero detectable per 100 mL.

At the time the samples are analyzed, the lab estimates the general bacterial population from background colony counts. Background bacteria are used as a general measure of the bacterial population present in a drinking water system or in the raw source water. Under ideal growth conditions, the background bacteria may increase and are indicators of the potential growth of coliforms. Initial counts are not reportable under our Permit to Operate. However, in order to identify problem areas and in aiming to provide good water quality within the distribution systems, all events are recorded and reported with follow-up sampling and, when necessary, flushing to provide fresh water to the site. 308 MF bacteriological samples were collected and analyzed at Caro Environmental Labs in Kelowna for total coliforms and E.coli. Additionally 171 P/A tests were analyzed (in-house). The P/A tests determine if total coliforms are present or absent from the sample but do not provide counts should the test be positive. P/A tests are collected on alternate weeks from the MF samples. The P/A tests provide quick feedback on the bacteriological quality of the water during the week that MF samples are not collected. Should a P/A be positive, additional bacteriological testing and further water chemistry testing occurs. At no time was E.coli detected in any DLC distribution systems.

In 2016 four samples were Positive for Total Coliforms. Three of the five bacteriological samples collected at the Coral Beach south end sampling site were positive for total coliforms and all were negative for E.coli. Presence Absence samples collected at the same time were negative. It was determined that a leak at the top of the yard hydrant sample site was the cause of intermittent positive total coliform counts; this leak was repaired. One sample on the Okanagan Lake source, Jardine pump station was positive for 1 total coliforms and no E.coli. Bacteriological sampling the following day were negative for total coliforms and E.coli. Appendix A contains a summary of positive total coliform results from each water system.

For all sources, any water chemistry parameters that are recorded daily through supervisory control and data acquisition (SCADA) and are not included in the data below. The monitoring of source and distribution water is conducted weekly rotating sampling through all sites as set out in the District of Lake Country Water Quality Monitoring and Reporting Plan.

Distribution water quality results are in tables 4 -9 below for District of Lake Country Water System (Beaver Lake Source (Table 4), Okanagan Lake source (Table 5), Oyama Lake Source (Table 6) Kalamalka Lake Source (Table 7) Coral Beach Water System (Table 8) and the Lake Pine Water System (Table 9). The list of sample sites for each distribution system is located in Appendix B.

2.3 Beaver Lake Source

Table 4. 2016 Annual Distribution Water Chemistry Results: District of Lake Country Water System; Beaver Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).

	Free Chlorine mg/L	Total Chlorine mg/L	Turbidity NTU	Temp °C	pH	Conductivity µS/cm
MIN	0.01	0.06	0.18	2	6.5	59
MAX	5.01	3.96	7.4	19	7.9	127
AVERAGE	1.37	1.34	1.28	12	7.0	73
WQ Guidelines				15	6.5-8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU AO</i>	<i>AO</i>	<i>AO</i>	

It should be noted that occasionally the distribution water sampled is a mixture of both sources (Okanagan Lake mixed into Beaver distribution) and variation from the norm occurs within the data.



Water chemistry equipment (residual chlorine and turbidity meters) at Eldorado Balancing Reservoir (above).

2.4 Okanagan Lake Source

Table 5. 2016 Annual Distribution Water Chemistry Results: District of Lake Country Water System; Okanagan Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).

	Free Chlorine mg/L	Total Chlorine mg/L	Turbidity NTU	Temp °C	pH	Conductivity µS/cm
MIN	0.01	0.02	0.25	5	7.4	162
MAX	4.41	5.10	3.05	17	8.4	389
AVERAGE	0.85	0.92	0.50	10	8.0	287
WQ Guidelines				15	6.5-8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU</i> AO	AO	AO	

It should be noted that there may be occasion where the distribution water sampled is a mixture of both sources (Okanagan Lake water mixed into Beaver distribution) and variation from the norm occurs within the data.

2.5 Oyama Lake Source**Table 6. 2016 Annual Distribution Water Chemistry Results: District of Lake Country Water System; Oyama Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).**

	Free Chlorine mg/L	Total Chlorine mg/L	Turbidity NTU	Temp °C	pH	Conductivity µS/cm
MIN	0.13	0.27	0.53	6	6.2	48
MAX	4.14	5.16	3.58	20	7.1	68
AVERAGE	2.59	2.89	1.12	13	6.6	56
WQ Guidelines				15	6.5- 8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU AO</i>	<i>AO</i>	<i>AO</i>	

Occasionally the distribution water sampled is a mixture of both sources (Oyama Lake and Kalamalka Lake) and variation from the norm occurs within the data.

2.6 Kalamalka Lake Source**Table 7. 2016 Annual Distribution Water Chemistry Results: District of Lake Country Water System; Kalamalka Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).**

	Free Chlorine mg/L	Total Chlorine mg/L	Turbidity NTU	Temp °C	pH	Conductivity µS/cm
MIN	0.05	0.19	0.29	4	7.7	332
MAX	2.82	3.20	2.2	16	8.5	448
AVERAGE	1.29	1.52	0.74	10	8.2	398
WQ Guidelines				15	6.5- 8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU AO</i>	<i>AO</i>	<i>AO</i>	

2.7 Coral Beach Water System**Table 8. 2016 Annual Distribution Water Chemistry Results: Coral Beach Water System; Okanagan Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).**

	Free Chlorine mg/L	Total Chlorine mg/L	Turbidity NTU	Temp °C	pH	Conductivity µS/cm
MIN	0.56	0.08	0.29	6	7.4	281
MAX	2.56	2.52	1.57	15	8.4	734
AVERAGE	1.16	1.30	0.54	11	8.0	339
WQ Guidelines				15	6.5-8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU AO</i>	<i>AO</i>	<i>AO</i>	

Conductivity of 734 verified by Caro Labs unknown why this measurement was higher than normal.

2.8 Lake Pine Water System**Table 9. 2016 Annual Distribution Water Chemistry Results: Lake Pine Water System; Okanagan Lake Source (All data reported from weekly water quality monitoring using hand-held equipment).**

	Chlorine mg/L	Chlorine mg/L	NTU	Temp °C	pH	µS/cm
MIN	0.05	0.18	0.25	5	7.6	284
MAX	4.18	4.38	0.87	17	8.2	330
AVERAGE	1.26	1.47	0.42	12	7.9	305
WQ Guidelines				15	6.5-8.5	
<i>Aesthetic objective (AO)</i>			<i>1 (max) ≤ 5 NTU AO</i>	<i>AO</i>	<i>AO</i>	

Distribution water quality can vary for numerous reasons. These include: seasonal changes to water demand, timing of sampling following system flushing or use of hydrant, or mixing of water sources. The last circumstance is only applicable to Beaver/Okanagan Lake customers and Oyama/Kalamalka Lake customers. Under normal operating procedures Beaver Lake and Okanagan Lake sources do not mix. However, should Beaver Lake source water experience an undesirable water quality event (i.e. high turbidity that occurs during freshet), and if the system demands are within an operational range, we will supplement or switch Beaver Lake source customers with Okanagan Lake water. For customers on the Oyama source this has been the third season that they have been supplied with Kalamalka Lake source during the non-irrigation season (approximately Oct through May). At no time are the Beaver or Oyama sources mixed into Okanagan or Kalamalka source distribution systems. If this were ever to occur it would be under a water emergency situation with the appropriate Water Quality Advisory Notification issued. It is not unusual in any of the distribution systems for free chlorine to read trace levels at dead ends or through low use areas. The free and total chlorine levels are closely monitored. If chlorine levels are low or turbidity is elevated chlorine dosing may be increased and/or flushing of distribution lines may occur. Follow-up sampling confirms residuals and turbidity levels.

2.9 Water Quality Advisory and Boil Water Notice

The following sources throughout 2016 were on a **Water Quality Advisory (WQA)**:

- Beaver Lake (District of Lake Country Water System)
- Oyama Lake (District of Lake Country Water System)

The advisories on Beaver and Oyama Sources will remain in effect until infrastructure upgrades are made to improve water quality and reliability.

Notice to customers on the Oyama and Beaver sources as to when their water supplies will be switched over or supplemented with an alternate water source of better water quality does not occur. The DLC will continue to supply customers with the best water quality possible and normal operations includes the switching and supplementing of alternate sources when possible. Notification would occur in a situation where there is a lower water quality event (such as a Water Quality Advisory condition).

Effective March 31st, 2006, Interior Health (IH) launched a Turbidity Notification Campaign wherein IHA required purveyors to issue a Water Quality Advisory when turbidity exceeds 1 NTU, and to contact Interior Health as the turbidity approaches 5 NTU to discuss enhanced notification (i.e. a Boil Water Notice). Reminder notifications are sent to customers annually through water bills inserts as well as posted on the DLC web page and through our social media as is required. Regardless whether a source is on an Advisory or not, the distribution systems on all sources are regularly monitored as per the IHA approved Water Quality Monitoring and Reporting Plan.

2.10 Service Disruptions

Under normal operating conditions many water utilities frequently experience minor disruptions due to various reasons such as repairs to leaks, water main breaks, seized valves or installation of new infrastructure. In 2016 water operations crew responded to approximately 15 service repairs and 3 water main breaks.

Two temporary BWN's specific to localized areas were required.

April 21 – 25: On Thursday April 21 an 8" valve failure occurred at the corner of Pretty and Middleton Roads. The water was shut off and all downstream users from this point were out of water. In conjunction with the Interior Health Authority a Boil Water Notice (BWN) for these customers was issued. In addition to following all requirements in the DLC's Deviation Response plan, all customers affected were hand delivered the BWN with explaining the reason of the water outage and that the BWN would remain in effect until Tuesday April 26th. DLC water operations staff worked all day to repair the break, flush the lines and restore water to customers by 4:30 pm. DLC staff also worked on the weekend to test water quality and collect Bacteriological samples so that the BWN could be removed on Monday April 25th. Rescind Notices were posted via our Deviation Response Plan protocols in addition to DLC staff hand-delivering to the affected businesses.



On September 22nd a broken service line during construction across from Lakewood mall, required water to be shut off while operations crew repaired and flushed the line. Boil Water Notices were hand delivered to the customers affected at the Lakewood Mall, trailer court and Daycare centre. Following bacteriological

sampling and adequate chlorine and turbidity results meeting the requirements of Interior Health, the BWN was lifted the morning of Sunday September 25th. All affected customers were hand delivered the notices.

All other mainline breaks at this site (across from the Lakewood Mall) were repaired by DLC operations staff. Positive pressure was maintained throughout these procedures with minimal interruption to customers. Lines were flushed to reduce any impact from fluctuating flows following the repair and sampling confirmed good water quality.

Most of the repairs required in 2016 were completed with little disruption and as quickly as possible. Regular service was restored within the day and public health and safety was not compromised. In circumstances where public health and safety are at risk due an interruption in water distribution services, the District reports the notable events to Interior Health Authority (IHA) and documented in the [Monthly Water Quality Reports](#) under *Notable Events*. With the exception of an emergency repair or break, customers are provided advanced notice. When this is not possible, customers in the affected area are advised and notifications are left on the doors of the residents.


2.11 Trihalomethanes (THM's)

Trihalomethanes (THM's) are a by-product of the water disinfection process. They form when natural organic matter (i.e. decaying vegetation commonly found in lakes and reservoirs) reacts with the chlorine used to treat the water. This reaction produces organic chlorites that include suspected carcinogenic "disinfection by-products," the most common of which are THM's.

The maximum acceptable concentration (MAC) for trihalomethane (*Trihalomethanes refers to the total of chloroform, bromodichloromethane, dibromochloromethane and bromoform* (THMs)) in drinking water is 0.100 mg/L (100 µg/L) based on a locational running annual average of a minimum of quarterly samples taken at the point in the distribution system with the highest potential THM levels. ([GCDWQ](#))

Trihalomethane analysis in the DLC Water System, Oyama and Beaver Lake sources had running averages that exceeding the CDWG. All THM results displayed at a running average are detailed in Figures 2-7.

Figure 2. 2002-2016 Moving Average of Total Trihalomethane (THM) Results for DLC Water System: Beaver Lake Source.



** 2002 and 2003 Data is limited to one sample date.*

Figure 3. 2006-2016 Moving Average of Total Trihalomethane (THM) Results for DLC Water System: Okanagan Lake Source.






Figure 4. 2004-2016 Moving Average of Total Trihalomethane (THM) Results for DLC Water System: Oyama Lake Source.



Range of Sampling on Oyama source now occurs only during irrigation season due to the switch to Kalamalka Lake source approximately Oct through May. 2013 onwards samples reduced from four to two.

Figure 5. 2004-2016 Moving Average of Total Trihalomethane (THM) Results for DLC Water System: Kalamalka Lake Source.



Range of Sampling on Kal source now also includes sampling within the Oyama distribution lines during non-irrigation season when the Kalamalka Lake source is the primary supply (approximately October through May). For years of 2013 onwards samples increased to four annually.

Figure 6. 2004-2016 Moving Average of Total Trihalomethane (THM) Results for Coral Beach Water System: Okanagan Lake Source.





Figure 6. 2004-2015 Moving Average of Total Trihalomethane (THM) Results for Lake Pine Water System: Okanagan Lake Source.



3. Instrument Calibration and Quality Control

Prior to sampling, field instruments are checked against standards to ensure accuracy. All equipment is regularly maintained and calibrated as required prior to use in the field. Annually, a representative from Hach Services personally attends the DLC to inspect, recalibrate and re-certify water quality hand-held equipment. 2016 certification was obtained for all water quality monitoring field equipment. On-line Water Quality monitoring equipment is verified weekly using the hand-held water quality equipment maintained and calibrated as per manufacture directions and certified by an outside agency as scheduled in the automated operational maintenance program.

4. Giardia Performance Monitoring: CT calculations

Beaver Lake Source

Chlorine is the primary disinfectant used on the Beaver Lake source and in order to be effective, it must have adequate contact time (CT) with microorganism to inactivate them. Various factors can affect CT values, such as pH, temperature, strength of disinfectants and types of organisms. The CT table that the DLC uses was developed by IHA specifically for the Beaver Lake source at the Glenmore pressure reducing Station (PR6), with the assumption that we are aiming to inactivate both *Giardia lamblia* (a single-celled parasite that causes intestinal infection) and viruses. Therefore the objective of giardia performance monitoring is to achieve a 3 log inactivation of giardia which is 99.9% deactivation which also provides the required 4 log inactivation of viruses. This PR station on Seaton Road has been working relatively well for collecting CT data. However, due to confined space and inadequate set up within that station this dedicated sample site was instead installed outside of the station and is subject to freezing in winter. Other than two occasions in 2016 when this site was sampled all CT requirements were met. On May 17TH 98.19% inactivation with triple chlorine concentration and 100% inactivation the following sample day. On

July 27th 92.87% inactivation with triple chlorine concentration within the following two hours achieving 100% inactivation. The CT spreadsheet is located in Appendix C. When Okanagan Lake source water is the primary source or supplemental source to Beaver Lake customers giardia performance contact time (CT) is not calculated. As such, there are no calculations for April 2016.

5. Source Sampling (Raw Water)

Raw Water Sampling occurs at intakes, upland drinking water reservoirs and at deep water intake pump stations.



Crooked Lake (left) Beaver Lake Dam(middle) and Vernon Creek (right)

At raw water intakes we analyze water quality parameters that will provide adequate measurement of chemical and physical water quality against the CDWG as per Conditions on Permit and recommendations in Oyama and Vernon Creek Watersheds Source Water Assessment. Annually, comprehensive tests are collected at all intakes and nutrient testing occurs as budget permits during high and low flow seasons or as required. The DLC continually modifies parameters sampled to provide sufficient baseline data for future water treatment.

Raw Water Data from intakes and pump stations are located in Tables 10 through 16 (below). Comprehensive tests were collected as follows:

- Beaver Lake source: Vernon Creek Intake (Table 11)
- Okanagan Lake Source: Okanagan Lake Pump Station (Table 12)
- Oyama Lake source: Oyama Creek Intake (Table 13)
- Kal Lake source: Kal Pump Station (Table 14)
- Coral Beach Water System
- Okanagan Lake Source: Coral Beach Pumphouse (Table 15)
- Lake Pine Water System
- Okanagan Lake Source: Lake Pine Pumphouse (Table 16)

*Subsequent comprehensive tests are planned for 2017.
Comprehensive reports are located in Appendix D.*



Oyama Lake Dam Spillway

Results are stored electronically and undergo verification prior to monthly and annual reporting to ensure quality controlled data. The data is used to characterize the quality of raw water intakes, monitor levels of physical, chemical and biological changes occurring in raw drinking water, establish trends in drinking water quality, identify and track the occurrence of concerns such as increased turbidity, positive bacteriological results or changes in nutrient loading. As well provide background data for future additional forms of disinfection and water treatment plant(s), assess and report on the state of the DLC's distribution and raw water quality.

Table 10. District of Lake Country Water System, 2016 Raw Water, Beaver Lake Source: Vernon Creek Intake/Eldorado Reservoir. All data reported from weekly water quality monitoring using hand-held equipment.

weekly sampling and on-line water quality equipment verification	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	³ % of samples less than 10 E.coli/100mL (N=52)
MIN	40	0.40	1.6	7.0	55	24	<1	<1	86%
MAX	80	2.52	17	8.3	96	75	380	23	
AVERAGE	69	1.25	9	7.6	68	39	40 samples		
WQ Guidelines			15	6.5-8.5			<1	<1	
Aesthetic objective (AO) Maximum Allowable Concentration (MAC)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC	

1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above

2 Turbidity is reported as weekly equipment verification and not SCADA

3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL



On July 17th a turbidity event occurred on the Beaver Lake Source following an intense rain storm event. Water operations staff quickly switched to the Okanagan Lake source. This changeover was only possible due to the immediate reduction of flows and ongoing wet weather over the following few days. On further investigation staff found many sections on the Beaver Lake road above the second cattle guard that had areas of substantial water erosion where sedimentation and high turbid water were draining to the Vernon Creek side. Many of the drainage structures were filled. The Ministry of Transportation and Infrastructure’s roads maintenance contractors were advised and asked to remediate this situation. Turbidity continued to elevate as each rain event occurred over the next 48 hrs.



It was also discovered that below the Dam a mud bogging area was discovered that also had very high potential for delivery of sediments to the creek. Many pictures of this area were taken and the site reported to the Natural Resource Sector of the Province both verbally and officially through their web based submission process.


DLC operators flushed the intake pond and cleaned screens until July 21st when the turbidity was less than 5NTU down from 100NTU and we could operate as normal again.

Water chemistry and bacteriological samples prior to the switch back showed low (normal) counts. A Boil Water Notice was adverted due to the quick response of the staff, the long days of work to clean the intake pond and the rains subsiding after day two.

Following this process we have received warning signage from the Province indicating the offence and fines associated with motorized vehicle damage in sensitive areas. These will be posted with the DLC watershed information signage at this site. A person(s) causing environmental damage on Crown Land may be subject

to a violation ticket of \$575, penalties of \$1000,000 and/or up to 1 year imprisonment. Unless the off road activities are reported in process or with substantiated evidence of the offender charges cannot be processed.

The drainage investigations in the high vulnerability areas directly along the creek, Beaver Lake Road and the unsanctioned off road activities below our intake all appear to be cumulative impact from sources of sediment that are contributing to high turbidity in our drinking water source.



If you notice questionable activities in our Community Watersheds report the incident to: 1-844-676-8477.

Table 11. District of Lake Country Water System, 2016 Raw Water, Okanagan Lake Source: Okanagan Lake Intake. All data reported from weekly verification of on-line monitoring equipment using hand-held water quality equipment.

Weekly sampling and on-line water quality equipment verification	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	UV Transmittance @ 254 nm unfiltered	³ % of samples less than 10 E.coli/100mL (N=30)
MIN	140	0.25	5	7.5	257	<5	<1	<1	86	100%
MAX	160	2.30	10	8.4	301	<5	110	1	88	
AVERAGE	153	0.42	7	8.1	277	<5	32 SAMPLES		87	
WQ Guidelines			15	6.5-8.5			<1	<1		
Aesthetic objective (AO) Maximum Allowable Concentration (MAC)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC		

1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above

2 Turbidity is reported as weekly equipment verification and not SCADA

3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL

Table 12. District of Lake Country Water System, 2016 Raw Water Oyama Creek Intake. All data reported from weekly verification of on-line monitoring equipment using hand-held water quality equipment.

weekly sampling and on-line water quality equipment verification w hen Oyama Creek online	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	³ % of samples less than 10 E.coli/100mL (N=21)
MIN	40	0.5	2.9	7.0	41	36	25	<1	58%
MAX	60	4	17.6	8.4	76	120	1700	130	
AVERAGE	44	1.1	11.4	7.5	55	51	29 samples		
WQ Guidelines			15	6.5-8.5			<1	<1	
Aesthetic objective (AO) Maximum Allowable Concentration (MAC)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC	

1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above

2 Turbidity is reported as weekly equipment verification and not SCADA.

3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL

Table 13 District of Lake Country Water System, 2016 Raw Water Kalamalka Lake Intake. All data reported from weekly verification of on-line monitoring equipment using hand-held water quality equipment.

weekly sampling and on-line water quality equipment verification	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	UVTransmittance @ 254 nm unfiltered	³ % of samples less than 10 E.coli/100mL (N=46)
MIN	200	0.25	6	7.8	366	<5	<1	<1	85	100%
MAX	220	3.33	15	8.8	428	<5	90	3	91	
AVERAGE	217	0.85	9	8.2	388	<5	51 Samples		90	
WQ Guidelines			15	6.5-8.5			<1	<1		
Aesthetic objective (AO)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC		

1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above

2 Turbidity is reported as weekly equipment verification and not SCADA.

3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL



Kalamalka Lake (left) and (right).

Table 14. Coral Beach Water System, 2016 Raw Water Coral Beach Intake (Okanagan Lake source). All data reported from weekly verification of on-line monitoring equipment using hand-held water quality equipment.

weekly sampling and on-line water quality equipment verification	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	UV Transmittance @ 254 nm unfiltered	³ % of samples less than 10 E.coli/100mL (N=49)
MIN	120	0.27	6	7.7	260	<5	<1	<1	32	100%
MAX	160	0.82	20	8.5	305	5	3	2	89	
AVERAGE	140	0.45	12	8.1	273	-	51 Samples		78	
WQ Guidelines			15	6.5-8.5			<1	<1		
Aesthetic objective (AO) Maximum Allowable Concentration (MAC)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC		
<p>1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above</p> <p>2 Turbidity is reported as weekly equipment verification and not SCADA.</p> <p>3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL</p>										

Table 15. Lake Pine Water System, 2016 Raw Water Lake Pine Intake (Okanagan Lake source). All data reported from weekly verification of on-line monitoring equipment using hand-held water quality equipment.

weekly sampling and on-line water quality equipment verification	¹ Hardness mg/L as CaCO ₃	² Turbidity NTU	Temp °C	pH	Cond µS/cm	TRUE color TCU	MF TOTAL CFU/100 ml	MF E.Coli CFU/100 ml	UV Transmittance @ 254 nm unfiltered	³ % of samples less than 10 E.coli/100mL (N=46)
MIN	140	0.20	8	7.4	264	<5	<1	<1	85	100%
MAX	160	0.58	15	8.3	339	<5	41	3	88	
AVERAGE	145	0.35	12	8.0	287	<5	44 Samples		86	
WQ Guidelines			15	6.5-8.5			<1	<1		
Aesthetic objective (AO) Maximum Allowable Concentration (MAC)	acceptable	1 (max) ≤ 5 NTU AO	AO	AO		AO	MAC	MAC		
<p>1 According to the criteria set out by the Guidelines for Canadian Drinking Water Quality (GCDWQ) the degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above</p> <p>2 Turbidity is reported as weekly equipment verification and not SCADA.</p> <p>3 According to the criteria set out by the BC Water Quality Guidelines (BCWQG) for a system using disinfection only to treat drinking water, "90% of samples should have less than 10 E.coli per 100mL" (BCWQG (Criteria) 2006). Results are % of samples less than 10 E.coli/100mL</p>										

5.1 Raw Water Reservoirs/Intakes

The District draws water from four main primary drinking water reservoirs:

1. Beaver Lake (Crooked Lake chain flows into Beaver Lake) Upland source with a downstream intake on Vernon Creek.
2. Oyama Lake (Damer Lake flows into Oyama Creek) Upland source with a downstream intake on Oyama creek
3. Okanagan Lake (3) deep water intake
4. Kalamalka Lake (1) deep water intake



Oyama Lake downstream dam (left) and Oyama Creek (right).

The Oyama and Vernon Creek watersheds together encompass approximately 141.1 km². Together, the two community watersheds supply the DLC with approximately 65% of their source water. Both watersheds are dependent on upland storage reservoirs that rely on snow pack for annual water regeneration and supply needs.

The DLC draws water from intakes both on Vernon and Oyama Creeks. In addition to monitoring and sampling at these intakes, the DLC also analyzes raw water from our upland drinking water reservoirs. These reservoirs have samples collected for other water quality parameters that would provide adequate measurement of chemical and physical water quality against the CDWG as per Conditions on Permit and recommendations in 2010 Oyama and Vernon Creek Source Water Assessment. Comprehensive reports (parameters tested at the drinking water intakes) are located in Appendix D and the result for nutrient sampling (upland drinking water reservoirs (Beaver and Oyama)) is contained in Appendix E

The District's two main upland drinking water reservoirs (Beaver and Oyama Lakes) and creek sources (Vernon and Oyama Creeks) exceeded the [GCDWQ](#) for colour and turbidity. Such results are common throughout the Okanagan wherever water is sourced from highland watersheds.

Source water from these watersheds is high in organic matter which causes colour issues and elevated disinfectant by-products. Turbidity is naturally occurring in some areas and can be compounded by human activities that occur above our intakes, such as recreation, cattle ranching and logging.

The water quality monitoring of these reservoirs may increase or decrease in response to varying water quality conditions and to provide adequate baseline data for future water treatment. Results are stored electronically and undergo verification prior to monthly and annual reporting to ensure quality controlled data. The data is used to characterize the raw water quality from our upland drinking water reservoirs, monitor levels of physical, chemical and biological changes occurring in raw drinking water, establish trends in drinking water quality, identify and track the occurrence of concerns such as increased turbidity, positive bacteriological results or changes in nutrient loading, provide background data for future additional forms of disinfection and water treatment plant(s) and to assess and report on the state of the DLC's distribution and raw water quality.




Beaver Lake Dam Intake

Algal blooms and other aquatic growth in our drinking water reservoirs can occur at various time throughout the year. Aquatic anomalies are assessed, under the direction of an aquatic biologist; samples are collected and sent for analysis.

The Eldorado balancing reservoir is monitored regularly and operations staff continues with on-going measures to control aquatic organism growth which includes the operation of the water as a balancing reservoir and the periodic removal of accumulated sediments. In 2016 this worked well and there were no major events that required additional control measures. There were no observed algae incidents on Oyama Lake or Oyama Creek.

Since 1998, when a taste and odour complaint occurred on Kalamalka Lake, the DLC, Greater Vernon Water/North Okanagan Regional District and the Ministry of Environment have partnered to acquire water quality data on this source. The information obtained defines the physical and biological impact at the DLC'S existing intakes; accumulates baseline water chemistry for future additional water treatment; provides information on the ideal depth of intakes for the best water quality; shows fluctuations in nutrients and algae production; and the implications of changes for water resources. This research is evaluated and re-directed on an annual basis.


As with previous years, late July Kalamalka Lake began to Marle and we saw the beautiful blue and turquoise green colours (pictures below). With this crystallization of calcium carbonate we also see a slight increase with this inorganic turbidity source. With very low bacterial counts and our chlorine maintained at adequate levels this did not cause additional problems other than regular cleaning and maintenance of equipment at our chlorination/UV facility. IHA was aware of this increased turbidity trending and has advised that a water quality advisory was not required.



*Marling:
Kalamalka Lake in
late July
(left) &
(right).*



6. Watershed Management



The DLC supplies domestic and irrigation water for the communities of Oyama, Winfield, Okanagan Centre, and Carr’s Landing. Sixty five (65%) percent of the water delivered to the Lake Country communities originates from the Oyama and Vernon Creek watersheds.

Infrastructure within these watersheds was constructed approximately 100 years ago for irrigation, but in the 1970’s the systems were updated, and evolved to become a major domestic water supply. As the service population continues to expand, there has been a significant increase on the demands of these watersheds. Both the Oyama and Vernon Creek watersheds are multi-use and have numerous ongoing activities (e.g. forestry, range, recreation, etc.). Under the BC Government’s Action Plan for Safe Drinking Water, the primary responsibility for protecting drinking water from land-use activities lies with the agency responsible for approving those activities. This can create complex governance that makes addressing source water concerns a significant challenge.

In 2010 the DLC secured an Okanagan Basin Water Board Water Quality and Conservation Grant that provided us with the substantial financial support to complete Watershed Source Water Assessment Plans. The DLC meets annually with stakeholders to review the plan, the intentions and recommendations/action items that were completed and other actions that have occurred or are required. The DLC also continues to collaborate with stakeholders (Forestry, Ranchers etc.) on other various occasions throughout the year to address matters as they arise. In 2015, the DLC fulfilled the second watershed related requirement of condition on permit to produce an implementation plan.

Watershed Source Water Assessment Plans:

- 2010 Oyama and Vernon Creek Source Water Assessment ([Watershed Protection Plan](#))]
- 2010 Source to Tap Assessment South Kalamalka Lake Intake (DLC water system)
- 2010 Source to Tap Assessment of the Okanagan lake Intake (DLC water system)
- 2015 [Source Water Assessment and implementation Plan: Oyama and Vernon Creek](#)



Damer Lake (above).

The purpose of the Source to Tap Assessments on the DLC distribution systems Kalamalka and Okanagan Lake sources were to conduct research and compile known data for use in identifying the DLC'S intake strengths, liabilities and planning for water quality protection and improvement. One of the most important recommendations in these assessments was the identification of an Intake Protection Zone. This zone defines the area where the intake should take precedence over every other use of consideration. It also defines the areas of land and water where special care must be taken in the use and handling of potential contaminants to prevent them from accidentally entering the lake and affecting the intake.

The Watershed Protection plan for the Oyama and Vernon Creek watersheds promotes sustainable management of our ecosystems through collaborative efforts of all stakeholders. The most valuable management tool from this plan is the identification of the various vulnerability zones that indicate the potential for risk to water quality. When considering any high risk activities within our community watershed, these high risk areas are the first to be evaluated for potential impacts of the activities along with the associated levels of risk. These activities may include forestry management, sports and/or recreational and mining activities.

Throughout the process of completing these plans, stakeholder involvement was a key component to ensuring a broad range of aspects were considered. The goal for stakeholders is to be aware of the vulnerability zones and to recognize the recommendations specific to them when planning further watershed activities.

The Oyama and Vernon Creek Source Water Assessment (SWA) was completed in 2010 as a condition on permit and prepared by Ecoscape Environmental Consultants Ltd. with input from all stakeholders.

Follow up meetings are for stakeholders to share their past accomplishments and current activities in the watershed. Overall, there is an appreciation and recognition our watersheds are multipurpose and it takes and overall effort to help protect the water while also sustainably maintaining resources for all users. Stakeholders are encouraged to bring forward their questions with an understanding that we want to maintain trust in this environment. As we continue to understand more of each stakeholder's processes and various regulations involved in their activities, recommendations can more often be dealt with through collaborative efforts. We recognize water is vitally important; however, we are all impacting the watershed regardless of what our activities are, we all have rights to be in the watersheds and we all have room for improvement.

The Source Water Assessment continues to play an important role in the management and planning in our community watersheds. In 2016 a specific stakeholder meeting to follow up on identified risks and actions in the SWA was not held. However, throughout 2016 there were various meetings (and continuous communications) either on a one-to one basis or in group settings with the Ministry of Agriculture, Ministry of Forest Lands and Natural Resource Operations, forestry licensees, range tenure holders, private lease lot cabin and resort owners, Okanagan Basin Water Board, Central Okanagan Regional District and the Ministry of Transportation and Infrastructure are among some of the parties the DLC worked with in 2016 respecting watershed activities. DLC staff also maintain other connections through involvement with several of the above-mentioned in various watershed related organizations some of which are the Okanagan Basin Water Board (OBWB), Okanagan Water Stewardship Council, BC Water Supply Association, Public Advisory Group for Sustainable Forest Management, OBWB and source protection and wetland committee.

We continue to improve our collaboration with the SWA stakeholders group, striving to implement recommendations and recognizing improvements as we move forward. Our watersheds are multipurpose, multijurisdictional and cumulatively we are all making an impact. All stakeholders have a responsibility to recognize this and use best practices maintaining sustainable resources for all users.

The DLC continued the joint work with Greater Vernon Water/North Okanagan Regional District (RDNO) and the Ministry of Environment to acquire water quality data on Kalamalka Lake. Data collected from 2016 sampling season was compiled and updated into the Kalamalka Lake Water Quality Study, Microflora, Water Chemistry & Thermal Profiles Report. The 2016 sampling season began in May and continued monthly into the fall; this marks the 18th year of collaboration on this comprehensive study.

6.1 Range Management

The Okanagan Shuswap District Range Program's annual meeting took place in the spring at the District of Lake Country. This year the meeting was expanded to include purveyors and ranchers within the Central Okanagan Regional District (DLC, Glenmore Ellison Irrigation District, Black Mountain Irrigation District, West Kelowna, South East Kelowna Irrigation District and Regional District North Okanagan (RDNO), Greater Vernon Water. There were over 40 people in attendance including stakeholders that presented information on watershed recreation sites and trails, timber licencees (Tolko, West Bank First Nations and BC Timber Sales) and research from UBCO, Range Branch and Ministry of Agriculture. Following this meeting the FLNRO Range Program facilitator provided minutes with action items to be addressed in the upcoming operating season.

Overall, the discussions this year focused on collaboration among local gov't, ranchers, Ministries within FLNRO), UBCO research and the new recreation sites and trails being developed. Again during 2016 the concern remained of the impact for (non-sanctioned and unknown but authorized) recreational activities in our watershed.

The meeting was quite large and for the DLC it is not the forum for individual discussions and specific updates with range use permit holders in our community watersheds. The DLC connects with ranchers (and others) throughout the year working to maintain open lines of communication with updates on projects, opportunities or situations that either party should be aware of.

Current Researchers/Projects in DLC and neighboring Community Watersheds:

- UBCO Research, Dr. Deborah Roberts, UBCO March 31, 2016 completed for FLNRO: [Verifying Best Management Practices \(BMPs\) for Livestock Grazing in Community Watersheds in the Okanagan Valley](#)
- UBCO 2016 initiated: Vulnerable distance to drinking water intakes for activities
- FLNRO: Managing Natural Range Barriers under the Forests and Range Practices Act
- Ministry of Agriculture [Silvopasture](#) project
- [MAY 2016, Persistence of Cryptosporidium parvum in Bovine Feces During Summer and Winter Exposure](#), Thesis by Keith Trizin

6.2 Forestry

Harvest activities in our community watershed continue to remain substantially decreased from previous years of major harvest and Mountain Pine Beetle salvage. The two major licencees in our watersheds, Tolko and BC Timber Sales again maintained low profile for harvest operations in 2016. Ongoing communications were maintained through staff involvement with the Sustainable Forest Management Plans, Public Advisory Group and direct contact as necessary.

Major Licencees in our community watersheds are well aware of our Watershed Protection Plan and the DLC has requested it be used as a planning tool when developing harvest plans. Harvest/site plans are reviewed by DLC staff and recommendations are provided as needed to address issues such as access (cattle and unsanctioned motorized vehicle activities), wild fire management, drainage concerns, and rehabilitation of roads to decrease the amount of non-status roads accumulating in our community watersheds.

Small Scale Salvage is a program that is regulated and operates through the Province. Private companies can apply for a small scale salvage licencee through the Ministry of Forest Lands and Natural Resources (MFLNR). These smaller operations apply to the MFLNR, harvest small volumes of timber that would otherwise not have been harvested and/or to address forest health objectives. Small scale salvage operations do not follow Forest Stewardship Plans or belong to a certification process such as Sustainable Forest Management Plan (SFMP). The SFMP includes a set of values, objectives, indicators and targets that address environmental, economic and social aspects of forest management... (excerpt extracted from Sustainable Forest Management Plan). Both major Licencees in the DLC's community watershed adhere to this plan. It is the responsibility of the small scale salvage operator and the Province to ensure that best management practices are being followed.

As with major licencees, when small scale salvage operations occur in DLC's watersheds, DLC staff review the referral for comment/recommendations and remind or provide the applicant a copy of our Watershed Protection Plan highlighting the importance of recognizing our vulnerability zones and properly planning and working within these zones. The DLC's highest concerns are within high vulnerability zones regardless of type of the proposed activity. The DLC continues to express concern with the Province authorizing approval for small scale salvage logging in high vulnerability zones (commonly within a major licensee's Lakeshore protection).

In early 2016 the Small Scale Salvage Program (SSSP) met with all participants (Licensees, contractors, professionals and purveyors (DLC and RDCO) to review changes in the SSSP *Manual effective May 2016*. The amendments do not directly address current ongoing issues within the community watersheds however; a new commitment to the responsibilities for SSS clients, such as electronic submissions of applications and documents will enable DLC staff to more clearly identify areas and respond to site in future applications.

For applications within Lakeshore Management zones the SSSP has been requesting the licensee follow Best Management practices and ensure appropriate cattle barriers are put in place after harvest. SSSP also advised they will monitor the logging during harvest and on completion to ensure adherence to the salvage plan. This is important when working in high vulnerability (i.e. lakeshore management zones) and of significant improvement over past Ministry protocol.

The Okanagan Shuswap District advises they will not regularly track ECA (equivalent Clear Cut Area) and rely on the comments from Major Licensee's to identify related issues in their feedback. The ECA not only can impact water quality but importantly it can influence water quantity (timing and volume). The DLC will continue requesting updates and address this information gap in our watershed implementation plans.

Access and roads appears to remain unchanged as the SSSP are currently reviewing the road use exemption to strengthen wording around maintenance and rehabilitation of roads. Currently, if trails into blocks appear to be left in such a way that ATV access might be an issue, SSSP informed the DLC they would try to work with the licensee to ensure restricted access. The SSSP advised they will continue to work with DLC if we observe and report SSS activities having a negative impact on roads and drainage.

The most significant improvement in SSSP planning is their agreement to now use the DLC vulnerability zone mapping in their future planning.

APPENDIX A – SUMMARY OF POSITIVE BACTERIOLOGICAN RESULTS IN DISTRIBUTION

	Total coliforms CFU/100 mL	E.coli CFU/100 mL	presence Absense (total coliforms)	presence Absense (E.coli)	sample date	Number of TC/E.coli Samples	Number of P/A samples	
District of Lake Country Water System:								
Beaver Lake Source (WQA)	none detected in distribtuion system					51	37	
Okanagan Lake Source	none detected in distribtuion system					59	27	
Jardine	1	<1			30/Aug/16			
Oyama Lake Source	none detected in distribtuion system					26	13	
Kalamalka Lake Source	none detected in distribtuion system					57	34	
Coral Beach Water System: Okanagan Lake Source						60	31	
Coral Beach South End	1	<1			8/Aug/16			
Coral Beach South End	1	<1			10/Aug/16			
Coral Beach South End	1	<1			30/Aug/16			
Coral Beach South End			1	<1	1/Sep/16			
Lake Pine Water System: Okanagan Lake Source						55	29	
						TOTAL:	308	171

Appendix B – DISTRICT OF LAKE COUNTRY SAMPLING SITES

District of Lake Country Water System: Beaver Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl2/NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	Sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
Vernon Creek Intake RAW	Beaver Lk		X									X												
Eldorado RAW	Beaver Lk		X			X		X																
Eldorado Reservoir/ chlorination facility	Beaver Lk					X				X			X											
Artella	Beaver Lk		X		X																			
Breakwater	Beaver Lk							X																X
Camp Rd Shop	Beaver Lk		X		X														X					
Camp Rd Reservoir (off line)	Beaver Lk		X							X														
Cooney Drain	Beaver Lk		X								X													
Mulberry	Beaver Lk		X				X																	
Devar Park	Beaver Lk		X		X																			X
Fire Admin Building	Beaver Lk		X		X									X										X
Jannery	Beaver Lk																							
Long	Beaver Lk		X			X																		X
Middleton Rd (future)	Beaver Lk		X												X									
McCreight	Beaver Lk		X		X																			X
Nighthawk	Beaver Lk		X			X																		
North View/Chase	Beaver Lk		X				X																	
Nygren	Beaver Lk		X																					
Pixton	Beaver Lk						X				X													X
Pow Rd PRV Stn	Beaver Lk		X							X														
PR2	Beaver Lk																							
PR6 Vernon Ck	Beaver Lk		X		X					X											X			
Williams	Beaver Lk		X		X		X																	X

District of Lake Country Water System: Okanagan Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl2/NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	Sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
Arena	Ok Lk			X											X									
Clement	Ok Lk		X					X																
Copper Hill	Ok Lk		X		X																			
Jardin Pump Stn	Ok Lk		X						X															
Lower Lakes Reservoir	Ok Lk		X			X				X														
McCoubrey	Ok Lk		X				X																	
Ok Bio Fuels (Jim Bailey Rd)	Ok Lk		X				X																	
Ok Lk Intake RAW	Ok Lk		X							X														X
Ok Lk Pump Stn/ chlorination facility	Ok Lk					X							X											
PR6 Ok Lk	Ok Lk		X							X														X
Ponderosa pumphouse	Ok Lk		X							X														
Ponderosa PRV stn	Ok Lk		X							X														
Ottley Rd (off Stubbs)	Ok Lk		X				X							X										
Upper Lakes Reservoir	Ok Lk		X					X																
Upper Zone (Future)	Ok Lk		X																					

District of Lake Country Water System: Oyama Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl2/NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	Sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
Easthill	Oyama Lk	X	X		X		X								X									
Oyama Rd S	Oyama Lk	X	X				X								X						X			
Oyama Rd N	Oyama Lk		X				X								X						X			
Oyama Lk/Hayton Rd	Oyama Lk			X															X					
Oyama Creek Intake RAW	Oyama Lk		X									X												
Oyama Reservoir	Oyama Lk		X										X									X		
Ribbleworth	Oyama Lk		X												X							X		
Sawmill Rd at Middlebench (Future)	Oyama Lk			X											X							X		
Talbot Rd Booster Stn (future)	Oyama Lk			X				X															X	
5410 Todd Rd. (summer: First customer Spring (Sawmill online): could be either from Sawmill or from reservoir)	Oyama Lk		X							X				X										
Oyama Creek Intake/Chlorination Facility - Chlorinator post reservoir	Oyama Lk											X			X									

District of Lake Country Water System: Kalamalka Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl2/NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	Sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
B-2 Reservoir	Kal			X				X							X									
Cornwall/ Sheldon	Kal		X	X			X								X			X				X		
Evans	Kal		X				X								X							X		
Kal Lk Intake RAW	Kal		X							X													X	
Kal Pump Stn	Kal		X			X				X											X			
Maclaren	Kal		X		X										X								X	
Sawmill Rd Booster (Future)	Kal		X												X									
Oyama Creek Chlorination Facility (distribution water from Kal Source (Sawmill)) to Oyama reservoir)	Kal					X							X											
Old Oyama Pumphouse	Kal									X					X									X
Teddy Bear (seasonal)	Kal		X							X					X					X				X

Coral Beach Water System: Okanagan Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl ₂ /NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	Sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
Coral Beach Intake RAW	CB OK LK		X			X						X		X									X	
Coral Beach Pump Stn	CB OK LK					X				X			X	X							X			
Coral Beach Pump Stn (distrib sample site)	CB OK LK		X					X					X	X										
Coral Beach Reservoir (Future)	CB OK LK		X												X							X		
Coral Beach South End	CB OK LK	X	X		X											X						X		

Appendix B (continued)
Lake Pine Water System: Okanagan Lake Source

MATRIX: Water Quality Sampling Sites, Criteria, Purpose, Type of sample Station	Source	THM	BacT/Water Chemistry	Free Cl ₂ /NTU when required	Yard Hydrant	Online WQ equipment verification	Eclipse #88	Hose bib	sink	Stainless port	Galvanised pipe	Continuous run	Point of Disinfection	First Customer	Intermediary	End of line	Chronic problem area	Stale water problem area	Seasonal only	Future Online CT monitoring site	Recommend install Eclipse #88	Sample Site Modification Required	Recommend not use	
Lake Pine Intake RAW	LP OK LK		X					X						X									X	
Lake Pine chlorination facility: dosing Booster/Lower Res	LP OK LK					X				X			X	X							X			
Lake Pine Booster/Lower Res	LP OK LK		X			X				X			X	X							X			
Lake Pine Lower Res	LP OK LK		X				X							X										
Lake Pine PR Stn.	LP OK LK	X	X													X						X		
Lake Pine Upper Reservoir	LP OK LK		X							X					X									

Appendix C – 2016 Giardia Performance Monitoring

DATE Jan	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1	6.90	2.00	14.00	1.80	3318.3	205.9	16.1	0.11	100.00	409124	1843	222	30.7
2	6.90	2.00	14.00	2.50	4608.8	216.3	21.3	0.12	100.00	409125	1844	222	30.7
3	6.90	2.00	14.00	2.10	3871.4	210.8	18.4	0.11	100.00	409126	1844	222	30.7
4	6.90	2.00	14.00	2.50	4608.8	216.3	21.3	0.12	100.00	409127	1844	222	30.7
5	6.90	2.00	14.00	1.87	3447.4	207.1	16.6	0.11	100.00	409128	1844	222	30.7
DATE Feb	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1	7.20	2.60	10.00	2.10	5419.9	226.7	23.9	0.09	100.00	409124	2581	159	43.0
2	7.25	2.80	10.00	2.03	5239.2	226.6	23.1	0.09	100.00	409125	2581	159	43.0
4	7.10	2.90	14.00	2.00	3687.0	212.3	17.4	0.12	100.00	409127	1844	222	30.7
5	7.20	2.70	14.00	1.99	3668.6	223.3	16.4	0.12	100.00	409128	1844	222	30.7
10	7.10	2.90	14.00	2.01	3705.5	212.4	17.4	0.12	100.00	409133	1844	222	30.7
11	7.04	2.80	14.00	2.40	4424.5	214.7	20.6	0.12	100.00	409134	1844	222	30.7
15	6.98	2.80	14.00	2.90	5346.3	215.9	24.8	0.12	100.00	409138	1844	222	30.7
16	6.98	2.70	15.00	3.00	5162.0	218.5	23.6	0.13	100.00	409139	1721	238	28.7
17	7.00	2.70	15.00	3.16	5437.3	221.9	24.5	0.13	100.00	409140	1721	238	28.7
18	6.98	2.71	13.00	2.90	5757.6	217.2	26.5	0.11	100.00	409141	1985	206	33.1
19	7.00	3.40	13.00	2.20	4367.9	200.2	21.8	0.10	100.00	409142	1985	206	33.1
22	6.98	3.70	13.00	1.99	3951.0	191.7	20.6	0.10	100.00	409145	1985	206	33.1
24	7.00	3.50	13.00	2.10	4169.4	197.4	21.1	0.10	100.00	409147	1985	206	33.1
29	6.90	3.50	12.00	2.00	4301.8	188.6	22.8	0.09	100.00	409152	2151	190	35.8
DATE March	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1	6.98	3.70	12.00	1.99	4280.0	191.7	22.3	0.09	100.00	409124	2151	190	35.8
2	7.00	3.80	12.00	1.80	3871.4	189.0	20.5	0.09	100.00	409125	2151	190	35.8
3	7.02	4.00	12.00	1.45	3118.6	181.8	17.2	0.08	100.00	409126	2151	190	35.8
4	7.08	4.00	12.00	1.10	2365.8	178.5	13.3	0.08	100.00	409127	2151	190	35.8
8	7.09	4.80	13.00	1.21	2402.3	171.9	14.0	0.09	100.00	409131	1985	206	33.1
10	7.15	5.00	13.00	1.13	2243.4	171.7	13.1	0.09	100.00	409133	1985	206	33.1
16	7.10	5.00	12.00	1.20	2581.0	170.0	15.2	0.08	100.00	409139	2151	190	35.8
21	7.20	5.00	14.00	1.10	2027.9	174.2	11.6	0.09	100.00	409144	1844	222	30.7
22	7.15	5.00	12.00	1.13	2430.5	171.7	14.2	0.08	100.00	409145	2151	190	35.8
23	7.50	5.80	12.00	0.56	1204.5	166.2	7.2	0.08	100.00	409146	2151	190	35.8
24	7.40	5.80	13.00	0.65	1290.5	163.9	7.9	0.08	100.00	409147	1985	206	33.1
30	7.30	6.60	14.00	0.85	1567.1	155.7	10.1	0.08	100.00	409153	1844	222	30.7
DATE MAY	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
2	7.02	10.80	280.00	1.21	111.5	110.4	1.0	1.20	99.91	409125	92	4439	1.5
3	6.70	11.40	260.00	1.88	186.6	99.8	1.9	1.01	100.00	409126	99	4122	1.7
4	6.60	10.10	177.00	1.59	231.8	102.3	2.3	0.70	100.00	409127	146	2806	2.4
9	6.80	11.90	318.00	1.70	138.0	98.8	1.4	1.22	99.99	409132	81	5041	1.4
10	6.80	11.80	284.00	1.43	130.0	96.9	1.3	1.07	99.99	409133	91	4502	1.5
11	6.98	11.80	180.00	1.71	245.2	106.8	2.3	0.75	100.00	409134	143	2853	2.4
12	6.80	11.80	233.00	1.95	216.0	101.6	2.1	0.92	100.00	409135	111	3694	1.8
16	6.75	13.30	270.00	1.80	172.1	88.7	1.9	0.93	100.00	409139	96	4280	1.6
17	6.80	12.40	270.00	0.48	45.9	79.0	0.6	0.83	98.19	409140	96	4280	1.6
18	6.83	13.80	267.00	1.57	151.8	86.6	1.8	0.90	100.00	409141	97	4232	1.6
19	7.80	13.00	252.00	2.03	207.9	136.0	1.5	1.33	100.00	409142	102	3995	1.7
24	6.95	11.60	192.00	1.51	203.0	105.5	1.9	0.78	100.00	409147	134	3044	2.2
25	6.67	12.80	265.00	1.25	121.7	84.2	1.4	0.86	100.00	409148	97	4201	1.6
26	6.97	12.50	213.00	1.43	173.3	98.7	1.8	0.81	100.00	409149	121	3376	2.0
30	6.86	11.60	130.00	2.56	508.3	109.8	4.6	0.55	100.00	409153	199	2061	3.3
31	6.93	12.30	154.00	2.48	415.7	107.0	3.9	0.64	100.00	409154	168	2441	2.8

Appendix C – 2016 Giardia Performance Monitoring (continued)

DATE June	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
2	6.79	13.90	247.00	1.79	187.0	86.3	2.2	0.83	100.00	409125	104	3915	1.7
3	6.60	13.70	276.00	1.98	185.2	82.3	2.2	0.88	100.00	409126	94	4375	1.6
6	6.80	17.10	439.00	1.72	101.1	69.0	1.5	1.17	100.00	409129	59	6959	1.0
7	7.00	17.10	410.00	1.85	116.5	75.4	1.5	1.20	100.00	409130	63	6499	1.0
8	6.91	17.40	340.00	1.69	128.3	70.4	1.8	0.93	100.00	409131	76	5390	1.3
9	6.91	16.20	343.00	2.32	174.6	80.2	2.2	1.07	100.00	409132	75	5437	1.3
10	7.45	17.40	201.00	2.07	265.8	88.8	3.0	0.69	100.00	409133	128	3186	2.1
13	6.80	13.40	125.00	2.94	607.0	96.7	6.3	0.47	100.00	409136	206	1982	3.4
14	7.32	13.60	118.00	2.04	446.2	110.0	4.1	0.50	100.00	409137	219	1871	3.6
15	6.96	13.50	157.00	2.03	333.7	96.7	3.5	0.59	100.00	409138	164	2489	2.7
16	7.15	13.00	246.00	1.27	133.2	100.3	1.3	0.96	99.99	409139	105	3900	1.7
20	6.67	12.50	168.00	3.56	546.9	96.5	5.7	0.63	100.00	409143	154	2663	2.6
21	6.98	13.30	213.00	1.95	236.3	98.2	2.4	0.81	100.00	409144	121	3376	2.0
22	7.17	13.70	213.00	1.35	112.0	97.2	1.2	1.17	99.97	409145	83	4930	1.4
23	6.99	13.70	237.00	1.49	162.3	92.1	1.8	0.85	100.00	409146	109	3757	1.8
27	7.13	14.90	256.00	0.90	90.7	82.9	1.1	0.82	99.95	409150	101	4058	1.7
28	7.20	16.10	336.00	1.52	116.8	84.7	1.4	1.10	99.99	409151	77	5326	1.3
29	7.10	16.00	412.00	1.71	107.1	83.6	1.3	1.33	99.99	409152	63	6531	1.0
30	7.19	16.90	445.00	1.47	85.3	79.4	1.1	1.37	99.94	409153	58	7054	1.0
DATE JULY	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
4	6.85	15.20	292.00	2.08	183.8	82.6	2.2	0.93	100.00	409127	88	4629	1.5
5	6.85	13.20	173.00	3.24	483.4	101.4	4.8	0.68	100.00	409128	149	2742	2.5
6	6.94	13.40	130.00	1.29	256.1	90.3	2.8	0.45	100.00	409129	199	2061	3.3
7	6.82	14.10	149.00	0.82	142.0	76.6	1.9	0.44	100.00	409130	173	2362	2.9
11	6.85	15.20	80.00	0.64	206.5	69.2	3.0	0.21	100.00	409134	323	1268	5.4
12	6.93	15.60	99.00	1.32	344.1	77.4	4.4	0.30	100.00	409135	261	1569	4.3
13	6.86	15.90	160.00	1.69	272.6	76.6	3.6	0.47	100.00	409136	161	2536	2.7
14	6.96	15.70	216.00	1.99	237.8	82.8	2.9	0.69	100.00	409137	119	3424	2.0
18	7.45	13.00	86.00	0.70	210.1	102.5	2.1	0.34	100.00	409141	300	1363	5.0
19	8.03	9.60	25.00	0.67	691.7	157.6	4.4	0.15	100.00	409142	1032	396	17.2
20	7.63	10.80	28.00	0.86	792.7	131.2	6.0	0.14	100.00	409143	922	444	15.4
21	6.83	14.70	201.00	3.52	452.0	91.8	4.9	0.72	100.00	409144	128	3186	2.1
25	6.84	16.30	363.00	1.82	129.4	74.7	1.7	1.05	100.00	409148	71	5754	1.2
26	6.78	17.30	355.00	1.68	122.1	67.3	1.8	0.93	100.00	409149	73	5627	1.2
27	7.40	17.50	356.00	0.35	25.4	66.4	0.4	0.92	92.87	409150	73	5643	1.2
27	6.96	17.70	356.00	3.68	266.8	79.0	3.4	1.09	100.00	409150	73	5643	1.2
28	6.97	17.70	358.00	1.44	103.8	68.9	1.5	0.96	100.00	409151	72	5675	1.2
29	6.80	18.20	350.00	2.02	149.0	65.5	2.3	0.89	100.00	409152	74	5548	1.2
DATE AUG	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1			327.00		0.0	0.0	#DIV/0!	0.00	#DIV/0!	409124	79	5184	1.3
2	7.65	16.70	277.00	3.00	279.5	105.9	2.6	1.14	100.00	409125	93	4391	1.6
3	6.83	16.60	205.00	3.10	390.3	79.0	4.9	0.63	100.00	409126	126	3250	2.1
4	6.87	16.80	282.00	2.78	254.4	77.8	3.3	0.85	100.00	409127	92	4470	1.5
8	6.58	16.90	380.00	2.20	149.4	66.5	2.2	0.98	100.00	409131	68	6024	1.1
9	7.00	16.70	350.00	2.70	199.1	82.1	2.4	1.11	100.00	409132	74	5548	1.2
10	6.90	16.60	280.00	2.56	236.0	78.9	3.0	0.86	100.00	409133	92	4439	1.5
12	6.93	17.10	361.00	2.48	177.3	76.7	2.3	1.07	100.00	409135	71	5723	1.2
15	6.90	18.00	366.00	3.02	213.0	73.4	2.9	1.04	100.00	409138	71	5802	1.2
16	7.00	18.20	362.00	2.68	191.1	73.9	2.6	1.04	100.00	409139	71	5738	1.2
17	6.79	18.70	360.00	2.36	169.2	64.5	2.6	0.90	100.00	409140	72	5707	1.2
18	7.11	18.10	368.00	2.44	171.1	76.5	2.2	1.09	100.00	409141	70	5834	1.2
19	6.93	17.20	364.00	3.10	219.8	78.8	2.8	1.11	100.00	409142	71	5770	1.2
22	7.63	16.80	291.00	3.18	282.1	105.3	2.7	1.19	100.00	409145	89	4613	1.5
23	7.38	16.60	298.00	3.20	277.2	98.4	2.8	1.14	100.00	409146	87	4724	1.4
24	6.93	16.00	299.00	3.20	276.2	86.0	3.2	1.00	100.00	409147	86	4740	1.4
25	7.61	15.10	358.00	3.00	216.3	112.6	1.9	1.56	100.00	409148	72	5675	1.2
26	7.04	16.00	314.00	3.18	261.4	89.7	2.9	1.09	100.00	409149	82	4978	1.4
29	6.92	16.50	282.00	3.28	300.2	83.1	3.6	0.91	100.00	409152	92	4470	1.5
30	7.32	16.70	302.00	3.20	273.5	95.0	2.9	1.11	100.00	409153	85	4787	1.4
31	6.88	16.80	303.00	3.22	274.3	79.9	3.4	0.94	100.00	409154	85	4803	1.4

Appendix C – 2016 Giardia Performance Monitoring (continued)

DATE SEPT	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1	6.99	16.50	290.00	3.60	320.4	86.6	3.7	0.97	100.00	409124	89	4597	1.5
2	6.81	16.70	228.00	5.01	567.1	89.6	6.3	0.79	100.00	409125	113	3614	1.9
6	6.92	13.80	263.00	4.40	431.8	104.7	4.1	1.07	100.00	409129	98	4169	1.6
12	7.17	13.40	265.00	2.11	205.5	106.1	1.9	1.09	100.00	409135	97	4201	1.6
14	6.90	12.70	265.00	3.06	298.0	106.2	2.8	1.09	100.00	409137	97	4201	1.6
19	6.94	12.70	263.00	3.90	382.7	111.8	3.4	1.14	100.00	409142	98	4169	1.6
28	6.99	12.40	264.00	3.40	332.4	114.0	2.9	1.17	100.00	409151	98	4185	1.6
30	7.10	12.20	265.00	3.50	340.9	121.1	2.8	1.24	100.00	409153	97	4201	1.6
DATE OCT	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
5	7.10	13.40	148.00		0.0	0.0	#DIV/0!	0.00	#DIV/0!	409128	174	2346	2.9
7	7.10	11.00	40.00	3.30	2129.3	130.5	16.3	0.20	100.00	409130	645	634	10.8
11	7.30	9.00	40.00	1.64	1058.2	145.4	7.3	0.23	100.00	409134	645	634	10.8
12	7.00	10.00	45.00	3.98	2282.7	138.5	16.5	0.24	100.00	409135	574	713	9.6
13	7.20	8.70	30.00	1.60	1376.5	142.6	9.7	0.17	100.00	409136	860	476	14.3
17	7.25	8.50	24.00	1.16	1247.5	140.3	8.9	0.13	100.00	409140	1075	380	17.9
19	7.30	8.60	20.00	1.35	1742.2	145.2	12.0	0.11	100.00	409142	1291	317	21.5
26	6.95	8.50	14.00	1.20	2212.3	125.9	17.6	0.07	100.00	409149	1844	222	30.7
27	7.30	9.50	20.00	1.33	1716.4	136.1	12.6	0.11	100.00	409150	1291	317	21.5
31	7.20	9.50	35.00	0.75	553.1	120.4	4.6	0.16	100.00	409154	737	555	12.3
DATE NOV	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
1	7.10	9.50	17.00	0.65	986.8	113.5	8.7	0.07	100.00	409124	1518	269	25.3
3	7.20	9.50	20.00	1.44	1858.3	132.8	14.0	0.10	100.00	409126	1290	317	21.5
4	7.18	8.40	14.00	0.80	1474.8	130.2	11.3	0.07	100.00	409127	1844	222	30.7
7	7.10	9.30	14.00	1.30	2396.6	127.7	18.8	0.07	100.00	409130	1844	222	30.7
9	7.00	8.50	14.00	1.30	2396.6	129.9	18.5	0.07	100.00	409132	1844	222	30.7
14	7.00	8.00	14.00	0.88	1622.3	126.8	12.8	0.07	100.00	409137	1844	222	30.7
15	7.10	7.90	14.00	1.16	2138.5	138.3	15.5	0.08	100.00	409138	1844	222	30.7
16	7.00	7.90	15.00	1.32	2271.3	135.7	16.7	0.08	100.00	409139	1721	238	28.7
17	7.70	6.90	17.00	1.71	2596.2	195.4	13.3	0.13	100.00	409140	1518	269	25.3
22	7.30	6.90	18.00	1.00	1433.9	156.2	9.2	0.11	100.00	409145	1434	285	23.9
23	6.60	7.00	12.00	0.92	1978.8	112.1	17.6	0.05	100.00	409146	2151	190	35.8
24	6.60	7.00	12.00	0.86	1849.7	115.6	16.0	0.05	100.00	409147	2151	190	35.8
28	6.30	6.82	13.00	1.01	2005.3	105.8	18.9	0.05	100.00	409151	1985	206	33.1
29	6.30	6.80	14.00	0.88	1622.4	103.8	15.6	0.06	100.00	409152	1844	222	30.7
31	6.30	6.80	14.00	0.80	1474.9	102.3	14.4	0.06	100.00	409154	1844	222	30.7
DATE DEC	pH (highest)	TEMP C (low est)	FLOW L/s	Free Cl PR6	CT achieved	CT Req'd	CTa/CTr	Free Cl Req'd	% Inactivation	TOT. VOL. USGAL	TIME (mins)	FLOW Usgpm	TIME (hrs)
5	7.20	5.50	11.00	0.80	1877.0	160.4	11.7	0.07	100.00	409128	2346	174	39.1
6	7.00	4.20	11.00	1.00	2346.3	168.3	13.9	0.07	100.00	409129	2346	174	39.1
8	6.95	3.20	11.00	0.55	1290.5	161.7	8.0	0.07	100.00	409131	2346	174	39.1
12	7.00	3.50	11.00	0.85	1994.4	172.4	11.6	0.07	100.00	409135	2346	174	39.1
13	7.00	3.50	11.00	0.80	1877.1	170.8	11.0	0.07	100.00	409136	2346	174	39.1
14	6.94	3.30	11.00	3.30	7742.9	209.3	37.0	0.09	100.00	409137	2346	174	39.1
15	6.95	2.70	11.00	3.30	7743.0	219.1	35.3	0.09	100.00	409138	2346	174	39.1
19	7.10	2.50	11.00	0.58	1360.9	181.3	7.5	0.08	100.00	409142	2346	174	39.1
20	7.10	2.50	11.00	0.60	1407.8	182.2	7.7	0.08	100.00	409143	2346	174	39.1
21	7.00	2.50	11.00	1.62	3801.1	203.5	18.7	0.09	100.00	409144	2346	174	39.1
22	7.00	2.50	11.00	1.40	3284.9	199.1	16.5	0.08	100.00	409145	2346	174	39.1
23	6.95	2.60	11.00	1.25	2933.0	190.7	15.4	0.08	100.00	409146	2346	174	39.1
24	6.95	2.50	12.00	2.50	5377.2	213.1	25.2	0.10	100.00	409147	2151	190	35.8
25	6.95	2.50	12.00	1.60	3441.4	199.3	17.3	0.09	100.00	409148	2151	190	35.8
26	6.95	2.50	13.00	1.90	3772.3	204.5	18.4	0.10	100.00	409149	1985	206	33.1
27	6.95	2.50	13.00	1.50	2978.1	197.4	15.1	0.10	100.00	409150	1985	206	33.1
28	6.95	2.50	12.00	2.50	5377.2	213.1	25.2	0.10	100.00	409151	2151	190	35.8
29	6.95	2.50	12.00	3.00	6452.7	219.0	29.5	0.10	100.00	409152	2151	190	35.8
30	6.95	2.50	11.00	2.50	5866.1	213.1	27.5	0.09	100.00	409153	2346	174	39.1
31	6.95	2.50	12.00	2.50	5377.3	213.1	25.2	0.10	100.00	409154	2151	190	35.8

Appendix D – Comprehensive Test Results

2016 Comprehensive Results							
Distribution Source		Beaver	Okanagan	Lake Pine	Coral Beach Source	Oyama	Kalamalka
Site		VERNON CREEK Intake	OK Pump House	LAKEPINE Pump House	CORAL BEACH Pump House	OYAMA CREEK Pump House	KALAMALKA Pump House
Date		16-May-16	18-May-16	18-May-16	18-May-16	16-May-16	17-May-16
Anions							
Chloride	mg/L	0.92	4.95	6.03	5.10	0.36	8.58
Chloride (AO)	mg/L	≤250	≤250	≤250	≤250	≤250	≤250
Fluoride	mg/L	<0.10	0.20	0.21	0.19	<0.10	0.32
Fluoride (MAC)	mg/L	1.5	1.5	1.5	1.5	1.5	1.5
Nitrogen, Nitrate as N	mg/L	0.038	0.082	0.159	0.028	0.018	0.080
Nitrate (MAC)	mg/L	10	10	10	10	10	10
Nitrogen, Nitrite as N	mg/L	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010
Nitrite (MAC)	mg/L	1	1	1	1	1	1
Sulphate	mg/L	2.7	30.4	32.9	30.4	3.2	51.2
Sulphate (AO)	mg/L	≤500	≤500	≤500	≤500	≤500	≤500
General Parameters							
Alkalinity (total)	mg/L	26	113	116	111	23	153
No current guidelines							
True Colour	CU	47	<5	<5	<5	48	<5
True Colour (AO)	CU	<15	≤15	≤15	≤15	≤15	≤15
Conductivity	uS/cm	61	287	301	286	54	412
No current guidelines							
Cyanide	mg/L	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010
Cyanide (MAC)	mg/L	0.2	0.2	0.2	0.2	0.2	0.2
pH	pH units	7.13	7.77	7.80	7.79	6.99	7.98
pH (AO)	pH units	6.5 - 8.5	6.5 - 8.5	6.5 - 8.5	6.5 - 8.5	6.5 - 8.5	6.5 - 8.5
Turbidity	NTU	1.60	0.20	0.27	0.48	0.73	4.65
Turbidity Guideline	NTU	<1	<1	<1	<1	<1	<1
Trans. 254 nm (unfiltered)	% T	42.7	86.4	86.8	86.3	40.1	88.2
No current guidelines							
Calculated Parameters							
Hardness (mg/L as CaCO ₃)	mg/L	30.6	127	134	148	25.3	197
No current guidelines							
Total Dissolved Solids/TDS	mg/L	33.2	165	174	173	29.5	243
TDS (AO)	mg/L	≤500	≤500	≤500	≤500	≤500	≤500
Total Recoverable Metals							
Aluminium (total)	mg/L	0.15	<0.05	<0.05	<0.05	0.09	<0.05
Aluminium (OG)	mg/L	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2
Antimony (total)	mg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Antimony (MAC)	mg/L	0.006	0.006	0.006	0.006	0.006	0.006
Arsenic (total)	mg/L	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Arsenic (MAC)	mg/L	0.01	0.01	0.01	0.01	0.01	0.01
Barium (total)	mg/L	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05
Barium (MAC)	mg/L	1	1	1	1	1	1
Beryllium (total)	mg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
No current guidelines							
Boron (total)	mg/L	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04
Boron (MAC)	mg/L	5	5	5	5	5	5
Cadmium (total)	mg/L	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Cadmium (MAC)	mg/L	0.005	0.005	0.005	0.005	0.005	0.005
Calcium (total)	mg/L	7.9	34.6	36.2	40.7	6.6	43.8
No current guidelines							
Chromium (total)	mg/L	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005
Chromium (MAC)	mg/L	0.05	0.05	0.05	0.05	0.05	0.05
Cobalt (total)	mg/L	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
No current guidelines							

Appendix D – Comprehensive Test Results (continued)


2016 Comprehensive Results							
Distribution Source	Beaver	Okanagan	Lake Pine	Coral Beach Source	Oyama	Kalamalka	
Site	VERNON CREEK Intake	OK Pump House	LAKEPINE Pump House	CORAL BEACH Pump House	OYAMA CREEK Pump House	KALAMALKA Pump House	
Date	16-May-16	18-May-16	18-May-16	18-May-16	16-May-16	17-May-16	
Total Recoverable Metals cont.							
Copper (total)	mg/L	0.005	<0.002	0.012	<0.002	0.002	<0.002
Copper (AO)	mg/L	≤1	≤1	≤1	≤1	≤1	≤1
Iron (total)	mg/L	0.31	<0.10	<0.10	<0.10	0.17	0.11
Iron (AO)	mg/L	≤0.3	≤0.3	≤0.3	≤0.3	≤0.3	≤0.3
Lead (total)	mg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Lead (MAC)	mg/L	0.01	0.01	0.01	0.01	0.01	0.01
Magnesium (diss.)	mg/L	2.6	9.9	10.6	11.2	2.2	21.3
No current guidelines							
Manganese (total)	mg/L	0.011	<0.002	0.003	<0.002	0.007	0.017
Manganese (AO)	mg/L	≤0.05	≤0.05	≤0.05	≤0.05	≤0.05	≤0.05
Mercury (total)	mg/L	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002	<0.00002
Mercury (MAC)	mg/L	0.001	0.001	0.001	0.001	0.001	0.001
Molybdenum (total)	mg/L	<0.001	0.004	0.005	0.005	<0.001	0.006
No current guidelines							
Nickel	mg/L	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
No current guidelines							
Phosphorus	mg/L	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2
No current guidelines							
Potassium (total)	mg/L	1.1	2.7	2.8	3.1	1.4	5.5
No current guidelines							
Selenium (total)	mg/L	<0.002	<0.005	<0.005	<0.005	<0.002	<0.005
Selenium (MAC)	mg/L	0.05	0.05	0.05	0.05	0.05	0.05
Silicon	mg/L	7	<5	<5	<5	5	<5
No current guidelines							
Silver	mg/L	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005
No current guidelines							
Sodium (total)	mg/L	2.0	12.7	14.1	14.3	2.0	19.5
Sodium (AO)	mg/L	≤200	≤200	≤200	≤200	≤200	≤200
Uranium (total)	mg/L	<0.0002	0.0022	0.0044	0.0025	<0.0002	0.0031
Uranium (MAC)	mg/L	0.02	0.02	0.02	0.02	0.02	0.02
Vanadium (total)	mg/L	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
No current guidelines							
Zinc (total)	mg/L	<0.04	0.81	0.08	0.05	<0.04	<0.04
Zinc (AO)	mg/L	≤5	≤5	≤5	≤5	≤5	≤5
Glossary of Terms, GCDWQ:							
<	Less than. Reported when result is less than the reported detection limit						
≤	Less than or equal to. Reported when result is less or equal to the reported detection limit						
AO	Aesthetic objective. Refer to GCDWQ						
MAC	Maximum acceptable concentration. Refer to GCDWQ						
OG	Operational guidance values. Refer to GCDWQ						
TCU	True color unit. Color referenced against a platinum cobalt standard						
NTU	Nephelometric turbidity unit						
uS/cm	Microsiemens per centimeter						
Hardness	The degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard, 180 mg/L and above.						


Appendix E – Nutrient Sampling Upland Drinking Water Reservoirs

2016 Nutrients				
Site		BEAVER	OYAMA	DAMER
Date		7-Jul-2016	7-Jul-2016	7-Jul-2016
Anions				
Nitrate as N	mg/L	<0.010	<0.010	<0.010
Nitrate (MAC)	mg/L	10	10	10
Nitrite N	mg/L	<0.010	<0.010	<0.010
Nitrite (MAC)	mg/L	1	1	1
Phosphate, as P	mg/L	<0.01	<0.01	<0.01
No current guidelines				
Sulfate	mg/L	2.3	1.6	< 1.0
Sulfate (AO)	mg/L	≤ 500	≤ 500	≤ 500
General Parameters				
Alkalinity, Total as CaCO ₃	mg/L	22	17	23
No current guidelines				
Alkalinity, Phenolphthalein as CaCO ₃	mg/L	<1	<1	<1
No current guidelines				
Alkalinity, Bicarbonate as CaCO ₃	mg/L	22	17	23
No current guidelines				
Alkalinity, Carbonate as CaCO ₃	mg/L	<1	<1	<1
No current guidelines				
Alkalinity, Hydroxide as CaCO ₃	mg/L	<1	<1	<1
No current guideline				
Ammonia as N	mg/L	0.118	0.062	0.088
No current guidelines				
Total Organic Carbon	mg/L	10.1	10.6	17.0
No current guidelines				
Dissolved Organic Carbon	mg/L	10.0	10.5	16.8
No current guidelines				
Chlorophyll-a	ug/L	0.9	2.3	1.5
No current guidelines				
Colour, True	CU	49	69	120
Colour(AO)	CU	≤15	≤15	≤15
Nitrogen, Total Kjeldahl	mg/L	0.34	0.38	0.59
No current guidelines				
Phosphorus, Total as P	mg/L	0.014	0.019	0.187
No current guidelines				
TDS	mg/L	64	44	64
TDS (AO)	mg/L	≤ 500	≤ 500	≤ 500
TSS	mg/L	<2	<2	<2
No current guidelines				
Calculated Parameters				
Hardness, Total as CaCO ₃	mg/L	30.4	17.1	25.5
No current guidelines				
Nitrate+ Nitrite as N	mg/L	<0.010	<0.010	<0.010
No current guidelines				
Total Nitrogen	mg/L	0.344	0.384	0.586
No current guidelines				
Organic Nitrogen	mg/L	0.226	0.322	0.498
No current guidelines				


2016 Nutrients				
Site		BEAVER	OYAMA	DAMER
Date		7-Jul-2016	7-Jul-2016	7-Jul-2016
Dissolved Metals (No current guidelines for dissolved metals)				
Total Dissolved Aluminium	mg/L	0.37	<0.05	0.11
Total Dissolved Antimony	mg/L	<0.001	<0.001	<0.001
Total Dissolved Arsenic	mg/L	<0.005	<0.005	<0.005
Total Dissolved Barium	mg/L	<0.05	0.06	0.06
Total Dissolved Beryllium	mg/L	<0.001	<0.001	<0.001
Total Dissolved Bismuth	mg/L	<0.001	<0.001	<0.001
Total Dissolved Boron	mg/L	0.07	0.13	0.11
Total Dissolved Cadmium	mg/L	<0.0001	<0.0001	<0.0001
Total Dissolved Calcium	mg/L	9.1	4.1	5.5
Total Dissolved Chromium	mg/L	<0.005	<0.005	<0.005
Total Dissolved Cobalt	mg/L	<0.0005	<0.0005	<0.0005
Total Dissolved Copper	mg/L	<0.002	<0.002	0.003
Total Dissolved Iron	mg/L	0.13	0.12	0.23
Total Dissolved Lead	mg/L	<0.001	<0.001	<0.001
Total Dissolved Lithium	mg/L	<0.001	0.001	0.002
Total Dissolved Magnesium	mg/L	1.8	1.7	2.8
Total Dissolved Manganese	mg/L	0.004	0.005	0.016
Total Dissolved Mercury	mg/L	<0.00002	<0.00002	<0.00002
Total Dissolved Molybdenum	mg/L	<0.001	<0.001	<0.001
Total Dissolved Nickel	mg/L	<0.002	<0.002	0.002
Total Dissolved Phosphorus	mg/L	0.4	<0.2	<0.2
Total Dissolved Potassium	mg/L	1.0	1.2	1.6
Total Dissolved Selenium	mg/L	<0.005	<0.005	<0.005
Total Dissolved Silicon	mg/L	<5	<5	<5
Total Dissolved Silver	mg/L	<0.0005	<0.0005	<0.0005
Total Dissolved Sodium	mg/L	2.3	2.5	2.9
Total Dissolved Strontium	mg/L	0.04	0.03	0.03
Total Dissolved Sulfur	mg/L	<10	<10	<10
Total Dissolved Tellurium	mg/L	<0.002	<0.002	<0.002
Total Dissolved Thallium	mg/L	<0.0002	<0.0002	<0.0002
Total Dissolved Thorium	mg/L	<0.001	<0.001	<0.001
Total Dissolved Tin	mg/L	<0.002	<0.002	<0.002
Total Dissolved Titanium	mg/L	<0.05	<0.05	<0.05
Total Dissolved Uranium	mg/L	<0.0002	<0.0002	<0.0002
Total Dissolved Vanadium	mg/L	<0.01	<0.01	<0.01
Total Dissolved Zinc	mg/L	<0.04	<0.04	<0.04
Total Dissolved Zirconium	mg/L	<0.001	<0.001	<0.001
Glossary of Terms, GCDWQ:				
<	Less than. Reported when result is less than the reported detection			
≤	Less than or equal to. Reported when result is less or equal to the			
AO	Aesthetic objective. Refer to GCDWQ			
MAC	Maximum acceptable concentration. Refer to GCDWQ			
OG	Operational guidance values. Refer to GCDWQ			
TCU	True color unit. Color referenced against a platinum cobalt standard			
NTU	Nephelometric turbidity unit			
uS/cm	Microsiemens per centimeter			
Hardness	The degree of hardness of drinking water may be classified in terms of its calcium carbonate concentration as follows: soft, 0 to <60 mg/L; medium hard, 60 to <120 mg/L; hard, 120 to < 180 mg/L; and very hard,			


APPENDIX F – BEAVER & OYAMA LAKE LEVELS AND DISCHARGE






APPENDIX G - DROUGHT FORECAST FOR BEAVER AND OYAMA LAKES





APPENDIX H – 2016 SOURCE AREA MAP



APPENDIX I - KALAMALKA UV STATION LOG SHEETS

January 2016

JANUARY 2016		FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power		
DAY	TIME	CHK'd	Totalizer 401 (m3)		Totalizer 402 (m3)	1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)			Validated Log	Bank 1 (KWH)	Bank 2 (KWH)
1	1030	J.R.	1730392	2157926	401/402	21.6	119.6	108.8	66.3	4.07	39	91.8	5.3	2.5
2	0830	J.R.	1730573	2158205	401/402	7.3	124.6	114.1	65.9	4.16	38	91.6	5.5	2.5
3	0830	J.R.	1732342	2158726	401/402							91.8		
4	930	R.S.	173957	2158363	401/402	71	172	194	62	4.27	39	92.3	6.0	2.9
5					401/402									
6	1605	J.R.	1731638	2158108	401/402	69	122	112	65.5	4.06	39	91.1	5.3	2.5
7	015	pm/r	1730202	2158219	401/402									
8					401/402									
9	0630	pm			401/402	66	122	110	63.2	3.95	39.44	91.4		
10	850	pm	1738008	2161430	401/402	67	120.4	111	62.3	4.07	37.76	91.4		
11	0920	pm	1739828	2161892	401/402							90.4		
12	1020	pm	1740318	2163034	401/402	72	178.4	201	63.8	4.27	39.4	94		
13	1015	pm	1741391	2163808	401/402	72	174	199	63.3	4.27	39.2	94		
14	500	R.S.	1742351	3164211	401/402	72	178	199	62	4.33	37	94	6.1	3.0
15	0850	J.R.	1742598	2166251	401/402							91.8		
16	1130	J.R.	174851	216717	401/402	79	125.3	107.1	65.9	3.14	37	92.1	5.2	2.5
17	1145	J.R.	1744053	2168312	401/402	68	125.9	112.9	65.5	4.05	39	91.9	5.3	2.5
18	1050	J.R.	1744223	2169326	401/402							92.1		
19	900	R.S.	1744283	3171445	401/402									
20	900	R.S.	1744576	3171813	401/402	67	134	108	62	4.28	39	92.6	4.3	2.5
21		J.R.	1745980	2173113	401/402	71	121	102	62	4.22	39	91.8	4.3	2.5
22	1200	R.S.	1746801	3173547	401/402	10	173	197	62	4.34	39	93	6.0	2.9
23	930	R.S.	1746355	3174041	401/402									
24	1000	R.S.	1749185	3175497	401/402									
25	0930	R.S.	1750579	3175851	401/402	71	179	199	62	4.26	39	90.8	6.0	2.9
26	0900	J.R.	1751142	2176142	401/402	70	124.6	107.1	64.5	4.07	39.6	91.5	4.3	2.5
27	830	R.S.	1751313	3177164	401/402									
28	830	R.S.	1752116	3178072	401/402	59	101	62	57	3.89	38	91.7	3.7	1.7
29	1115	J.R.	1753100	2179442	401/402	70.3	120.1	105.5	61.7	4.06	39	91.8	4.3	2.2
30					401/402									
31					401/402									
JANUARY					401/402									

MARCH 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	1515	J.A	1778161	2199449	401/402									
2	1030	R.B	1779777	2199483	401/402									
3	1320	J.A	1779949	2200549	401/402	59.4	102.3	68.5	57.1	3.98	39.7	92.1	3.7	1.2
4	0915	J.R	1780125	2201314	401/402						0	91.9		
5	915	R.B	1781631	2201492	401/402									
6	930	R.B	1781826	2201858	401/402	73	127	109	67	4.05	39	90.8	4.3	2.5
7	930	J.R	1782249	2202201	401/402						0	91.5		
8	1500	R.B			401/402									
9	1020	J.A	1783789	2203773	401/402	99.7	82.9	97.7	70.8	4.29	38	91.6	3.8	1.8
10	900	R.B	1784038	2205043	401/402	95	79	90	70	4.25	38	91.5	3.8	1.8
11	1430	J.R	1785250	2205478	401/402						0	91.6		
12	0950	J.A	1785872	2205654	401/402	97.6	81.7	94	72	4.22	39	91.8	3.8	1.8
13	0950	J.R	1785970	2207253	401/402						0	91.6		
14	1000	J.A	1786988	2207427	401/402	95.6	79.7	98.6	70.6	4.22	39	91.9	3.8	1.8
15	0920	J.R	1787785	2207598	401/402						0	91.8		
16	0940	J.A	1787968	2209146	401/402						0	91.8		
17	830	R.B	1789770	2209544	401/402									
18	530	M.B	1790833	2210095	401/402	97.5	83.5	80.7	71.8	4.36	37	92.5	3.8	1.8
19	810	M.B	1792495	2210280	401/402									
20					401/402									
21	1145	J.R	1792600	2211067	401/402	59.5	103.5	63.7	58.5	3.81	39	91.8	3.7	1.7
22	630	R.B	1793778	2212221	401/402									
23	830	R.B	1794304	2213400	401/402									
24	1030	J.R	1794488	2213330	401/402	59.9	104.3	64.4	58.6	3.82	39	91.8	3.7	1.7
25					401/402									
26					401/402									
27					401/402									
28					401/402									
29	1120	J.R	1798278	2216734	401/402	59.8	103.9	66.2	58.3	3.87	38	91.6	3.8	1.7
30	0820	J.R	1798663	2217622	401/402	70.1	124	106.9	69.6	4.03	39	91.3	4.3	2.5
31	1200	J.R	1798662	2218702	401/402						0	91.8		
MARCH					401/402									

MAY 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	1100	ROB	1840615	2271325	401/402	149	136	139	128	3.99	83	91.9	6.1	2.9
2	1150	J.R.	1893285	2279432	401/402	127.5	255.1	169.5	126.1	3.78	85.19	92.3	7.6	3.7
3	1200	J.R.	1896539	2282456	401/402	156.8	139.4	152.3	131.6	3.91	84	91.8	6.0	2.9
4	1310	J.R.	1800182	2295532	401/402	122.9	250.8	166.8	115.3	3.88	80.2	91.9	7.6	3.7
5	1600	J.R.	1902607	2297579	401/402	170.6	191.2	200.8	153	4.16	86	91.2	7.9	3.7
6	1120	J.F.	1904069	2299089	401/402	166	170	152	136	4.19	84	87	6.0	2.8
7	0730	J.A.	1905666	2301247	401/402						0	92.8		
8	1060	J.A.	1907971	2304032	401/402						0	93.1		
9	1300	J.A.	1910790	2306659	401/402	117.9	133.2	141.2	126.9	3.93	81.3	91.8	6.1	2.9
10	1600	J.A.	1913559	2309198	401/402	135	152.7	151.1	166.5	4.0	87	91.7	5.2	2.8
11	1630	J.A.	1916411	2311692	401/402	159.6	150.9	166.6	137.1	3.9	83	91.8	6.1	2.9
12	1540	J.A.	1918619	2313765	401/402						0	91.6		
13	1400	ROB	1920997	2316325	401/402									
14					401/402									
15					401/402									
16	1100	J.A.	1931031	2323969	401/402	153.6	142.9	146.2	134.6	3.96	85	91.6	6.1	2.9
17	0950	J.A.	1933384	2327186	401/402						0	91.8		
18	0950	J.A.	1936930	2329319	401/402	157.8	159.7	146.1	136.4	4.03	86	91.9	6.0	2.8
19	1015	J.A.	1939835	2331864	401/402	157.6	161.7	165.6	133.6	3.99	86	91.4	6.0	2.9
20	1120	J.A.	1942310	2334298	401/402	150.3	132.2	136.8	127	3.91	85	91.2	6.0	2.9
21	0930	J.F.	1944312	2336590	401/402	147	164	153	136	4.22	83	93	6.0	2.8
22	1030	J.F.	1945817	2338040	401/402							95.9		
23	0900	J.F.	1947338	2339629	401/402	138	131	134	126	3.90	82	91	6.0	2.9
24	1000	J.F.	1949066	2341523	401/402	128	158	147	135	4.04	81	91	6.0	2.8
26	1300	ROB	1951416	2344577	401/402	197	169	150	138	4.07	85	92	5.9	2.8
27	1030	ROB	1956307	2350401	401/402						0			
27	0900	M.A.	1957983	2352061	401/402									
28	0800	M.A.	1959686	2353754	401/402									
29	1110	J.A.	1961501	2355213	401/402						0	91.8		
30	0855	J.R.	1962750	2356996	401/402						0	91.9		
31	0855	J.R.	1962750	2356996	401/402						0	91.6		
MAY					401/402									

JULY 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	8:45	TF	2031705	2430553	401/402	173	160	176	143	4.20	87	95	5.9	2.8
2	8:45	TF	2036501	2433272	401/402	200	194	185	160	4.28	89	92	7.7	3.9
3	9:30	TF	2042592	2434827	401/402	197	181	184	161	4.22	90	97	7.7	3.7
4	WVI	ROR	2043582	2440538	401/402	205	187	192	164	4.26	89	93	7.9	4.0
5	12:0	J.R.	2056262	2455527	401/402	173.9	115.7	178.7	149.8	5.17	81.18	91.6	6.1	2.8
6					401/402									
7	9:30	ROR		2447615	401/402									
8	10:00	TF	2046834	2450128	401/402							92.5		
9	8:00	ROR	2048305	2451660	401/402									
10	10:30	ROR	2049609	2452905	401/402									
11	11:00	ROR	2050471	2453733	401/402									
12	08:45	J.R.	2051365	2455613	401/402	-	-	-	-	-	8	91.8	-	-
13	8:00	ROR	2052600	2455534	401/402	141	130	137	131	3.92	80	91.7	5.9	3.0
14	10:00	ROR	2054803	2457495	401/402									
15	12:00	J.R.	2056587	2459436	401/402							91.5		
16	9:15	HRU	2057352	2460815	401/402			187	151.3					
17	7:00	HRU	2058595	2461303	401/402	184.2	152.6	175.5	157.3	4.33	78	91.9	7.7	4.2
18	11:30	ROR	2061015	2463592	401/402	152	154	167	141	4.00	86	91.3	6.0	2.8
19	07:50	J.R.	2061015	2463680	401/402	132	124.9	131.4	121.4	2.91	83	91.8	5.8	3.0
20	07:40	J.R.	2062141	2464939	401/402						8	91.7		
21	08:00	J.R.	2063573	2467066	401/402						8	91.5		
22	8:30	ROR	2066801	2468634	401/402	183	170	186	153	4.25	97	91.2	7.5	4.1
23	8:45	TF	2070594	2473966	401/402	172	161	178	145	4.18	89	93	7.6	4.1
24	10:15	TF	2074138	2477689	401/402	182	173	187	155	4.20	97	93	7.5	4.1
25	14:30	J.R.	2077687	2480292	401/402						8	91.8		
26	11:10	J.R.	2080208	2485464	401/402	140.1	144.2	156.8	149.6	4.2	91.24	91.6	5.9	2.8
27	08:37	J.R.	2080478	2491849	401/402	123.3	162.4	182.7	159	4.07	88.71	91.6	7.6	4.1
28	11:00	J.R.	2082277	2496744	401/402	150.6	153.3	165.8	162	4.00	84.5	91.4	5.9	2.8
29	13:15	J.R.	2086133	2501348	401/402	173.8	155.4	180.2	149	4.17	88.6	91.8	7.5	4.1
30	08:50	J.R.	2092491	2501348	401/402	178	170.2	179.1	136.4	5.13	89.5	91.6	7.5	4.1
31	08:50	J.R.	2096024	2504782	401/402						8	91.6		
JULY					401/402									

AUGUST 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	0915	J.R.	2098451	2508354	401/402	193.6	204.0	225.9	141.8	4.12	89.6	91.6	2.8	3.8
2	1300	J.R.	2102143	2511969	401/402	151.2	166.2	166.4	141.3	4.05	89.3	91.4	6.0	2.8
3	1230	J.A.	2104103	2514593	401/402	120.5	166.9	76.4	149.5	4.14	86	91.6	2.2	4.1
4	1130	TI			401/402									
5	7:30	TF	2109480	2519066	401/402	177	171	179	152	4.23	86	92.2	7.6	4.1
6	8:30	TF	2116101	2524083	401/402	172	208	227	159	4.19	89	91.8	2.6	3.7
7	8:45	TF	2118410	2528837	401/402	136	207	220	162	4.14	91	91.0	2.9	3.8
8	12:45	TF	2122378	2533717	401/402	172	204	221	161	4.03	91	89.9	2.6	3.7
9	11:00	TF			401/402									
10	11:00	TF	2128064	2541407	401/402	177	212	228	164	4.07	90	89.6	2.2	3.2
11	0950	J.R.	2131828	2543269	401/402	183	214.4	232.2	143.3	4.18	86	91.6	2.2	3.6
12	0950	J.R.	2134955	2546142	401/402						0	91.9		
13					401/402									
14					401/402									
15	1030	Rob	2143411	2556266	401/402	168	205	220	157	4.04	89	90.0	2.7	3.7
16	1045	J.R.	2150612	2556809	401/402	174.9	192.7	230.3	141.2	4.16	92.1	91.5	2.9	3.8
17	8:00	Rob	2150652	2564001	401/402	161	200	215	150	4.09	91	92.5	2.7	3.7
18	7:30	Rob	2157261	2564623	401/402	161	198	187	149	4.06	91	91.8	2.5	4.1
19	8:00	Rob	2159137	2570655	401/402	164	204	219	155	4.07	91	91.6		
20	1000	Rob	2162035	2571545	401/402	154	187	177	149	3.89	93	90.3	2.5	4.1
21	1030	Rob	2169402	2583810	401/402	157	188	182	147	4.00	86	90	2.6	4.1
22	1345	J.A.	2172456	2587167	401/402	165.1	212.9	225.0	102	4.09	89	91.4	2.8	3.8
23					401/402									
24	0911	J.R.	2176515	2590969	401/402	166	207.3	192.2	149.3	4.2	89.5	91.5	2.6	4.1
25	0855	J.R.	2178479	2593256	401/402						0	91.5		
26	1100	J.R.	2187142	2597277	401/402	158.3	194.6	182.5	147.7	3.98	89	90.2	2.5	4.1
27					401/402									
28	6:30	M.R.M.	2189534	2602934	401/402	166.3	209	195.4	149	4.17	89	92	2.6	4.1
29	1020	J.R.	2192503	2605988	401/402						0	91.5		
30	0915	J.R.	2194695	2609622	401/402	163	208.5	194.3	150.9	4.18	89.6	91.6	2.7	4.2
31	0945	J.R.	2198538	2612866	401/402	148.2	212	214.1	147.5	3.96	89.5	91.1	2.8	3.8
					401/402									

SEPTEMBER 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	830	ROB	2206931	2615935	401/402	160	200	158	147	4.08	84	90.7	7.6	4.1
2	0940	J.A.	2207281	2618059	401/402	153.6	223	225.9	138.2	4.16	82	92.1	7.8	3.8
3	0730	J.A.	2204319	2619393	401/402						0	91.8		
4	0830	J.A.	2205780	2620812	401/402						0	91.2		
5	1004	J.A.	2207187	2622250	401/402	154	218.2	220.7	134.8	4.05	85	91.9	7.9	3.8
6	1210	J.A.	2208994	2624990	401/402	163	210	195.1	149.8	4.09	83.3	90.4	7.7	4.2
7	1020	J.A.	2210961	2625831	401/402						0	90.3		
8	0940	J.A.	2211809	2626900	401/402						0	91.6		
9	1130	ROB	2213094	2627694	401/402	163	211	197	148	4.13	81	90.4	7.7	4.2
10					401/402									
11		ROB	2215163	2628444	401/402									
12	1230	J.A.	2216326	2630809	401/402	140.1	218.7	219.8	131.5	3.97	84.2	91.1	7.9	3.8
13					401/402									
14	1130	ROB	2217601	2633880	401/402	134	213	216	128	3.93	85	90.3	7.9	3.8
15	0905	J.A.	2222005	2636069	401/402						0	91.1		
16	0940	J.A.	2224646	2639064	401/402	153.9	202.9	188.4	153.1	4.06	85	91.5	7.7	4.2
17					401/402									
18					401/402									
19	1500	J.A.	2231920	2645371	401/402						0	91.9		
20	1430	J.A.	2232267	2646905	401/402						0	91.6		
21	0800	ROB	2233593	2648165	401/402									
22	0915	TF	2233953	2648949	401/402							91.7		
23	0930	J.A.	2234261	2649745	401/402						0	91.0		
24	1000	TF	2235285	2650555	401/402							91		
25	0930	TF	2236096	2651372	401/402							90.9		
26	1145	J.A.	2237264	2651932	401/402						0	91.8		
27	1030	J.A.	2238438	2652824	401/402						0	91.9		
28	1350	J.A.	2240230	2654311	401/402						0	91.8		
29	1300	J.A.	2241324	2655741	401/402	140.2	191.0	171.9	136.0	3.98	85.3	91.6	7.7	4.2
30	1300	J.A.	2242971	2657270	401/402	145.1	192.5	171.8	133.5	4.06	84	91.8	7.7	4.2
31					401/402									
SEPTEMBER					401/402									

OCTOBER 2016			FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power	
DAY	TIME	Chk'd	Totalizer 401 (m3)	Totalizer 402 (m3)		1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)	Validated Log			Bank 1 (KWH)	Bank 2 (KWH)
1	1115	J.A.	2244411	2658826	401/402						0	91.6		
2	1130	J.A.	2246963	2660496	(401/402)	138.1	192.5	189.5	131.1	4.01	863	91.8	7.7	4.1
3	1250	J.A.	2249480	2660691	401/402	180.9	221.6	243.3	161.2	4.27	859	91.9	7.9	3.8
4	1000	J.A.	2251080	2662263	(401/402)	149	206.5	124.0	131.2	4.03	88	91.8	7.7	4.1
5					401/402									
6	1050	J.A.	2254120	2665340	401/402						0	91.8		
7	930	R.B.	2255694	2666557	401/402									
8	900	R.B.	2257015	2668382	(401/402)	140	185	170	130	4.01	81	91.8	7.7	4.2
9					401/402									
10	1000	R.B.	2258256	2671235	401/402	172	203	229	155	4.21	83	90.9	7.8	3.8
11					401/402									
12					401/402									
13	1540	J.A.	2260141	2673118	401/402						0	91.9		
14	1330	T.F.	2261362	2673569	401/402							92.3		
15					401/402									
16					401/402									
17					401/402									
18	930	R.B.	2261460	2674618	401/402									
19	900	R.B.	2261664	2674992	401/402									
20	1330	R.B.	2262066	2675170	401/402									
21	1030	R.B.	2262245	2675547	401/402									
22					401/402									
23					401/402									
24	1400	R.B.	2263210	2676384	401/402									
25	830	R.B.	2263335	2676475	401/402						39			
26		R.B.	2263874	2677134	401/402	70	78	77	67	4.02	39	91.1	3.5	1.7
27	1000	R.B.	2264540	2679003	401/402	67	84	91	63	4.01	39	91.3	4.3	2.0
28	9100	T.F.	2265310	2679401	401/402							92.4		
29	1000	T.F.	2266311	2679540	401/402							93.7		
30	7100	T.F.	2266311	2681151	401/402							91.9		
31	1100	R.B.	2268029	2681337	401/402									
OCTOBER					401/402									

DECEMBER 2016		FLOW		Running Reactor	Lamp Intensity			Dosage		Flow (LPS)	UVT %	Power		
DAY	TIME	Chk'd	Totalizer 401 (m3)		Totalizer 402 (m3)	1 (W/m2)	2 (W/m2)	3 (W/m2)	UV SP (W/m2)			Validated Log	Bank 1 (KWH)	Bank 2 (KWH)
1			2294376	2703374	401/402	75	77	80	67	4.16	38	91.6	3.8	1.7
2	4:15	RAS	2294543	2703499	401/402	70	73	76	66	4.15	39	92.9	3.7	1.6
3					401/402									
4					401/402									
5	12:15	J.A.	2292569	2705777	401/402						0	91.5		
6	13:15	J.R.	2293573	2705952	401/402	69.1	86.2	92.1	65.7	4.0	39	91.1	4.2	2.0
7					401/402									
8	10:25	J.A.	2294	2701691	401/402	71	84.5	94.5	75.6	4.05	38	91.6	4.3	2.7
9	10:40	R.O.S.	2295106	2707439	401/402	66	85	93	64	3.86	39	91.2	4.3	2.6
10	11:40	J.R.	2295918	2709768	401/402						0	91.5		
11	11:40	J.R.	2296619	2709569	401/402									
12			2297950	2709748	401/402									
13	10:25	J.A.	2298134	2710735	401/402	69.3	73.9	78.5	63.8	4.06	39.6	91.8	3.7	1.7
14	11:10	J.R.	2298481	2711691	401/402	68.5	86.9	96.6	62.9	4.05	39.2	91.5	4.3	2.6
15	10:30	R.O.S.	2299688	2711881	401/402									
16			2300076	2713409	401/402									
17					401/402									
18	10:20	R.O.S.	2301948	2713767	401/402									
19	10:20	R.O.S.	2302143	2715350	401/402									
20	10:00	R.O.S.	2303364	2715458	401/402	67	85	95	67	4.07	39	91.6	4.3	2.6
21	11:00	R.O.S.	2305209	2715438	401/402									
22	09:30	J.R.	2307825	2715661	401/402	71.0	76	79.0	61.4	4.12	38.1	91.8	3.8	1.7
23	11:20	J.R.	2307573	2717260	401/402						0	92.0		
24	9:20	J.F.	2307878	2717438	401/402	68	77	98	63	4.01	39	91.7	4.3	2.6
25	09:10	J.F.	2307384	2717613	401/402									
26	10:15	J.A.	2309590	2719109	401/402									
27	11:20	J.R.	2311077	2719295	401/402	67.7	82.6	88.2	63.1	4.04	37	91.8	4.2	2.6
28	08:50	J.A.	2311530	2719580	401/402									
29	11:50	J.R.	2311719	2721074	401/402									
30	08:45	J.R.	2313183	2721263	401/402									
31	08:50	J.A.	2313371	2722005	401/402	69.7	74.7	78.8	65.7	4.05	39	91.6	3.2	1.4
DECEMBER					401/402									

APPENDIX J –ENVIRONMENTAL OPERATORS CERTIFICATION PROGRAM (EOCP) OPERATOR’S CERTIFICATION

The EOCP Board of Directors, with the approval of the Ministry of Health, recently changed the water treatment facility definition. As such, since our chlorination facilities are method of *primary disinfection*, to produce potable water, they are now classified as water treatment facilities.

According to the [EOCP](#) Primary disinfection can include chlorination and ultraviolet of with we utilize alone or combined in our facilities. With this new definition, Operators are now required to update their certification to include water treatment. With the EOCP and Ministry of Health changing our facility classifications to Water Treatment facilities, Section 12 of the BC Drinking Water Protection Regulation requires that our operators now must now also obtain Water Treatment Certification through the EOCP. This was an unexpected expense and time allocation; not all operators were in approved in 2016 to obtain certification. All operators now are also required to accumulate operator experience toward Water Distribution and Water Treatment certification.

Name	Certification No.	Level
Mike Mitchell	1839	WD-IV, CH, WT-I
Rob Witzke	1841	WD-II, CH
Patti Meger	4838	WT-I, CH, WD-I, T-I
Kiel Wilkie	6503	WD-III, CH
Tyler Friedrich	7697	WD-II, WT-I
Julius Rideg	6827	WD-I, CH, MWWT-OIT, WT-I
Mike Kristensen	8344	WD-I, WT-I